

**DIRECTORATE OF ALTERNATIVE  
ENERGY**

**BIDDING DOCUMENT**

FOR PROCUREMENT OF SOLAR PV  
SYSTEMS FOR SCHOOLS IN DISTRICT  
SUJAWAL



**ENERGY DEPARTMENT  
GOVERNMENT OF SINDH**

# Contents

INVITATION FOR BIDS .....	1
INSTRUCTIONS TO BIDDERS.....	5
A. GENERAL .....	5
IB.1 Scope of Bid & Source of Funds .....	5
1.1 Scope of Bid.....	5
1.2 Source of Funds.....	5
IB.2 Eligible Bidders.....	5
IB.3 Cost of Bidding .....	5
B.    BIDDING DOCUMENTS .....	5
IB.4 Contents of Bidding Documents .....	5
IB.5 Clarification of Bidding Documents .....	6
IB.6 Amendment of Bidding Documents (SPP Rules 22(2) & 22).....	6
C.    PREPARATION OF BIDS.....	6
IB.7 Language of Bid.....	6
IB.8 Documents Comprising the Bid .....	6
IB.9 Sufficiency of Bid.....	6
IB.10 Bid Prices, Currency of Bid and Payment.....	7
IB.11 Documents Establishing Bidder’s Eligibility and Qualifications .....	7
IB.12 Documents Establishing Works’ Conformity to Bidding Documents .....	7
IB.13 Bid Security .....	7
IB.14 Validity of Bids, Format, Signing and Submission of Bid.....	8
D.    SUBMISSION OF BID.....	8
IB.15 Deadline for Submission, Modification & Withdrawal of Bids .....	8
E.    BID OPENING AND EVALUATION .....	9
IB.16 Bid Opening, Clarification and Evaluation (SPP Rules 41, 42 & 43) .....	9
IB.17 Process to be Confidential .....	11

F. AWARD OF CONTRACT.....	12
IB.18. Post Qualification.....	12
IB.19 Award Criteria & Procuring Agency’s Right.....	12
IB.20 Notification of Award & Signing of Contract Agreement .....	12
IB.21 Performance Security .....	13
IB.22 Integrity Pact.....	13
BIDDING DATA .....	14
1.13 Detailed requirement of Solar PV Systems for Fifteen (15) Water Pumping Station in District Tharparkar:.....	20
FORM OF BID AND SCHEDULES TO BID .....	32
FORM OF BID (LETTER OF OFFER).....	32
PREAMBLE TO SCHEDULE OF PRICES .....	35
1. General.....	35
2. Description .....	35
3. Units & Abbreviations .....	35
4. Rates and Prices .....	35
5. Bid Prices.....	36
6. Provisional Sums and Day work .....	36
SCHEDULE - A TO BID: SCHEDULE OF PRICES – SUMMARY OF BID PRICES .....	37
A. Price Schedule of Solar PV Systems: .....	37
SCHEDULE - B TO BID : SPECIFIC WORKS DATA .....	38
SCHEDULE – C TO BID: PROPOSED PROGRAMME OF WORKS .....	65
SCHEDULE – D TO BID: METHOD OF PERFORMING WORKS .....	67
SCHEDULE – E TO BID: (INTEGRITY PACT) .....	68
CONDITIONS OF CONTRACT & CONTRACT DATA .....	69
CONDITIONS OF CONTRACT.....	70
2. THE PROCURING AGENCY .....	72
3. ENGINEER’S/PROCURING AGENCY’S REPRESENTATIVES.....	72

4. THE CONTRACTOR.....	72
5. DESIGN BY CONTRACTOR.....	73
6. PROCURING AGENCY’S RISKS.....	73
7. TIME FOR COMPLETION.....	74
8. TAKING-OVER.....	75
9. REMEDYING DEFECTS.....	75
10. VARIATIONS AND CLAIMS.....	75
11. CONTRACT PRICE AND PAYMENT.....	77
12. DEFAULT.....	78
13. RISKS AND RESPONSIBILITIES.....	79
14. INSURANCE.....	80
15. RESOLUTION OF DISPUTES.....	80
16 INTEGRITY PACT.....	81
CONTRACT DATA.....	82
STANDARD FORMS.....	86
FORM OF BID SECURITY (Bank Guarantee).....	87
FORM OF PERFORMANCE SECURITY (Bank Guarantee).....	89
FORM OF CONTRACT AGREEMENT.....	91
MOBILIZATION ADVANCE GUARANTEE.....	93
INDENTURE FOR SECURED ADVANCES.....	95

# INVITATION FOR BIDS



## GOVERNMENT OF SINDH DIRECTORATE OF ALTERNATIVE ENERGY ENERGY DEPARTMENT

NO. DAE/Solar/154/2022

dated: 9<sup>th</sup> June, 2023

### NOTICE INVITING TENDER

The Directorate of Alternative Energy, Energy Department, Government of Sindh invites sealed bids from interested bidders for Supply, Installation and Operation & Maintenance of Solar PV Systems for Schools in districts Dadu, Shikarpur, Tharparkar, Umerkot, Sanghar, Badin and Sujawal separately under different ADP schemes.

**Scope of Work:** Supply, Installation of Solar PV Systems at Schools in districts Dadu, Shikarpur, Tharparkar, Umerkot, Sanghar, Badin and Sujawal separately under different ADP schemes, 3 years Operation & Maintenance services with online monitoring system connected with concerned DISCOs for Net Metering (if possible) with the following details:

**Solar PV Systems required for each district are as follows:**

S/No.	District	No. of Solar PV Systems	Types of Solar PV System	Quantity	Package
1	Dadu	50	8.6 kWp	9	Package 1
			10.2 kWp	19	
			15.1 kWp	18	
			28.5 kWp	1	
			33.4 kWp	3	
2	Shikarpur	48	10.2 kWp	39	Package 2
			13.5 kWp	5	
			33.4 kW	4	
3	Tharparkar	63	8.6 kWp	40	Package 3
			10.2 kWp	9	
			15.1 kWp	13	
			33.4 kWp	1	
4	Umerkot	74	3.2 kWp	3	Package 4
			5.4 kWp	57	
			10.2kWp	3	
			15.1 kWp	6	
			28.5 kWp	5	

5	Sanghar	54	8.6 kWp	21	Package 5
			13.5 kWp	15	
			15.1 kW	18	
6	Badin	43	8.6 KW	19	Package 6
			10.2 kW	11	
			15.1 kWp	8	
			58.8 kW	5	
7	Sujawal	154	1.08 kWp	33	Package 7
			2.1 KW	78	
			3.2 kWp	19	
			5.4 kW	5	
			8.6 kWp	13	
			15.1 kW	3	
			28.5 kW	3	

**Eligibility:** Valid registration with tax authorities (Federal & Provincial) and Pakistan Engineering Council

**Method of Procurement:** Single Stage Two Envelope

**Bidding/Tender Documents:**

**Issuance:** Complete set of bidding document of each package separately can be obtained from date of publication to **27<sup>th</sup> June, 2023 till 11:00 am** upon submission of a written application and payment of a non-refundable fee of Rs.5000/- (Cash) or downloaded from Sindh Public Procurement Regulatory Authority's website or Energy Department's website i.e. [www.sindhenergy.gov.pk](http://www.sindhenergy.gov.pk) and be submitted along with the said fee.

**Submission:** Bids completed in all aspects must be submitted on or before **27<sup>th</sup> June, 2023 till 03:30 pm** and must be accompanied by a bid security of 2.5% of the total bid price in shape of Demand Draft or Bank Guarantee in favor of the Sindh Alternative Energy Fund.

**Opening:** Bids of each package separately will be opened on **27<sup>th</sup> June, 2023 at 04:00 pm.**

**Place of Issuance, Submission, Inquiries & Opening:**

**Address:** Energy Department, 3<sup>rd</sup> Floor, State Life, Building No. 3, Opp. CM House, Karachi.

**Telephone Number:** 02199207144, **Fax:** 02199206276

**Terms & Conditions:**

Under the following conditions bid will be rejected:

- i. Conditional and telegraphic bids/tenders;

- ii. Bids not accompanied by bid security of required amount and form;
- iii. Bids received after specified date and time;
- iv. Bids submitted by black listed firms; and
- v. Incomplete bids as per instructions given in bidding document

**Bid Validity Period:** Ninety (90) days

**Quoted Price Validity:** Quoted price for Supply & Installation of Solar PV Systems shall be valid for Financial Years 2022–23, 2023–24 and quoted price for Operation & Maintenance services shall be valid for subsequent three financial years.

Each contractor/firm may apply for more than one package separately by submitting bids separately.

The procuring agency reserves the right to reject any or all bids subject to the relevant provisions of Sindh Public Procurement Rules 2010 (Amended 2019)

**IMTIAZ ALI SHAH  
DIRECTOR  
Alternative Energy**

## INSTRUCTIONS TO BIDDERS & BIDDING DATA

### **Notes on the Instructions to Bidders**

This section of the bidding documents provides information necessary for bidders to prepare responsive bids, in accordance with the requirements. It also gives information on bid submission, opening and evaluation, and on the award of contract.

Matters governing the performance of the Contract or payments under the Contract, or matters affecting the risks, rights, and obligations of the parties under the Contract are not normally included in this Section, but rather in the appropriate sections of the *Conditions of Contract* and/or *Contract Data*.



## ***INSTRUCTIONS TO BIDDERS***

Note: *These Instructions to Bidders (IB) along with Bidding Data will not be part of Contract and will cease to have effect once the Contract is signed).*

### **A. GENERAL**

#### **IB.1 Scope of Bid & Source of Funds**

##### **1.1 Scope of Bid**

The Procuring Agency as defined in the Bidding Data (hereinafter called the Procuring Agency) wishes to receive Bids for the Works summarized in the Bidding Data (hereinafter referred to as the Works).

Bidders must quote for the complete scope of work. Any Bid covering partial scope of work will be rejected as non-responsive.

##### **1.2 Source of Funds**

The Procuring Agency has arranged funds from Government of Sindh.

#### **IB.2 Eligible Bidders**

2.1 Bidding is open to all firms and persons meeting the requirements as given in the bidding data.

#### **IB.3 Cost of Bidding**

3.1 The bidder shall bear all costs associated with the preparation and submission of its bid and the Procuring Agency will in no case be responsible or liable for those costs, regardless of the conduct or outcome of the bidding process (SPP Rules 24 & 25).

### **B. BIDDING DOCUMENTS**

#### **IB.4 Contents of Bidding Documents**

4.1 In addition to Invitation for Bids, the Bidding Documents are those stated below, and should be read in conjunction with any Addendum issued in accordance with Sub-Clause IB.6.1.

1. Instructions to Bidders & Bidding Data
2. Form of Bid, Qualification Information & Schedules to Bid

Schedules to Bid comprise the following:

- i. Schedule A: Schedule of Prices/ Bill of Quantities (BoQ).
- ii. Schedule B: Specific Works Data
- iii. Schedule C: Proposed Program of Works
- iv. Schedule D: Method of Performing Works
- v. Schedule E: Integrity Pact

3. Conditions of Contract & Contract Data

4. Standard Forms:

- i. Form of Bid Security,
- ii. Form of Performance Security;

- iii. Form of Contract Agreement;
- iv. Form of Bank Guarantee for Advance Payment

5. Specifications

6. Drawings, if any

### **IB.5 Clarification of Bidding Documents**

5.1 A prospective bidder requiring any clarification(s) in respect of the Bidding Documents may notify the Engineer/Procuring Agency at the Engineer's/ Procuring Agency's address indicated in the Bidding Data.

5.2 An interested bidder, who has obtained bidding documents, may request for clarification of contents of bidding documents in writing and procuring agency shall respond to such queries in writing within three calendar days, provided they are received at least five calendar days prior to the date of opening of bid (SPP Rule 23-1).

### **IB.6 Amendment of Bidding Documents (SPP Rules 22(2) & 22)**

6.1 At any time prior to the deadline for submission of Bids, the Procuring Agency may, for any reason, whether at his own initiative or in response to a clarification requested by a interested bidder, modify the Bidding Documents by issuing addendum.

6.2 Any addendum thus issued shall be part of the Bidding Documents pursuant to Sub – Clause 6.1 hereof, and shall be communicated in writing to all purchasers of the Bidding Documents. Prospective bidders shall acknowledge receipt of each addendum in writing to the Procuring Agency.

6.3 To afford interested bidders reasonable time in which to take an addendum into account in preparing their Bids, the Procuring Agency may at its discretion extend the deadline for submission of Bids.

## **C. PREPARATION OF BIDS**

### **IB.7 Language of Bid**

7.1 All documents relating to the Bid shall be in the language specified in the Contract Data.

### **IB.8 Documents Comprising the Bid**

8.1 The Bid submitted by the bidder shall comprise the following:

- i. Offer /Covering Letter
- ii. Form of Bid duly filled, signed and sealed, in accordance with IB.14.3.
- iii. Schedules (A to E) to Bid duly filled and initialed, in accordance with the instructions contained therein & in accordance with IB.14.3.
- iv. Bid Security furnished in accordance with IB.13.
- v. Power of Attorney in accordance with IB 14.5.
- vi. Documentary evidence in accordance with IB.2(c) & IB.11
- vii. Documentary evidence in accordance with IB.12.

### **IB.9 Sufficiency of Bid**

9.1 Each bidder shall satisfy himself before Bidding as to the correctness and sufficiency of his Bid and of the premium on the rates of CSR / rates and prices quoted/entered in the Schedule of Prices, which rates and prices shall except in so far as it is otherwise expressly provided in the Contract,

cover all his obligations under the Contract and all matters and things necessary for the proper completion of the works.

9.2 The bidder is advised to obtain for himself at his own cost and responsibility all information that may be necessary for preparing the bid and entering into a Contract for execution of the Works.

#### **IB.10 Bid Prices, Currency of Bid and Payment**

10.1 The bidder shall fill up the Schedule of Prices (Schedule A to Bid) indicating the percentage above or below the Composite Schedule of Rates/unit rates and prices of the Works to be performed under the Contract. Prices in the Schedule of Prices/Bill of Quantities shall be quoted entirely in Pak Rupees keeping in view the instructions contained in the Preamble to Schedule of Prices.

10.2 Unless otherwise stipulated in the Conditions of Contract, prices quoted by the bidder shall remain fixed during the bidder's performance of the Contract and not subject to variation on any account.

10.3 The unit rates and prices in the Schedule of Prices or percentage above or below on the composite schedule of rates shall be quoted by the bidder in the currency as stipulated in Bidding Data.

10.4 Items for which no rate or price is entered by the Bidder will not be paid for by the Procuring Agency when executed and shall be deemed covered by the other rates and prices in the Bill of Quantities.

#### **IB.11 Documents Establishing Bidder's Eligibility and Qualifications**

11.1 Pursuant to Clause IB.8, the bidder shall furnish, as part of its bid, documents establishing the bidder's eligibility to bid and its qualifications to perform the Contract if its bid is accepted.

11.2 Bidder must possess and provide evidence of its capability and the experience as stipulated in Bidding Data and the Qualification Criteria mentioned in the Bidding Documents.

#### **IB.12 Documents Establishing Works' Conformity to Bidding Documents**

12.1 The documentary evidence of the works' conformity to the Bidding Documents may be in the form of literature, drawings and data and the bidder shall furnish documentation asset out in Bidding Data.

12.2 The bidder shall note that standards for workmanship, material and equipment, and references to brand names or catalogue numbers, if any, designated by the Procuring Agency in the Technical Provisions are intended to be descriptive only and not restrictive.

#### **IB.13 Bid Security**

13.1 Each bidder shall furnish, as part of his bid, at the option of the bidder, a Bid Security as percentage of bid price/estimated cost or in the amount stipulated in Bidding Data in Pak. Rupees in the form of *Deposit at Call/ Payee's order or a Bank Guarantee* issued by a Scheduled Bank in Pakistan in favor of the Procuring Agency valid for a period up to twenty eight (28) days beyond the bid validity date (*Bid security should 2.5% of the bid price/estimated cost SPP Rule 37*).

13.2 Any bid not accompanied by an acceptable Bid Security shall be rejected by the Procuring Agency as non-responsive.

13.3 The bid securities of unsuccessful bidders will be returned upon award of contract to the successful bidder or on the expiry of validity of Bid Security whichever is earlier.

13.4 The Bid Security of the successful bidder will be returned when the bidder has furnished the required Performance Security, and signed the Contract Agreement (SPP Rule 37).

13.5 The Bid Security may be forfeited:

- a) if a bidder withdraws his bid during the period of bid validity; or
- b) if a bidder does not accept the correction of his Bid Price, pursuant to Sub-Clause 16.4 (b) hereof; or
- c) in the case of a successful bidder, if he fails within the specified time limit to:
  - i. furnish the required Performance Security or
  - ii. sign the Contract Agreement.

#### **IB.14 Validity of Bids, Format, Signing and Submission of Bid**

14.1 Bids shall remain valid for the period stipulated in the Bidding Data after the date of bid opening.

14.2 In exceptional circumstances, Procuring Agency may request the bidders to extend the period of validity for an additional period but not exceeding 1/3 of the original period. The request and the bidders' responses shall be made in writing or by cable. A Bidder may refuse the request without forfeiting the Bid Security. A Bidder agreeing to the request will not be required or permitted to otherwise modify the Bid, but will be required to extend the validity of Bid Security for the period of the extension, and in compliance with IB.13 in all respects (SPP Rule 38).

14.3 All Schedules to Bid are to be properly completed and signed.

14.4 No alteration is to be made in the Form of Bid except in filling up the blanks as directed. If any alteration be made or if these instructions be not fully complied with, the bid may be rejected.

14.5 Each bidder shall prepare original and number of copies specified in the Bidding Data of the documents comprising the bid as described in IB.8 and clearly mark them "ORIGINAL" and "COPY" as appropriate. In the event of discrepancy between them, the original shall prevail.

14.6 The original and all copies of the bid shall be typed or written in indelible ink and shall be signed by a person or persons duly authorized to sign (in the case of copies, Photostats are also acceptable). This shall be indicated by submitting a written Power of Attorney authorizing the signatory of the bidder to act for and on behalf of the bidder. All pages of the bid shall be initialed and official seal be affixed by the person or persons signing the bid.

14.7 The Bid shall be delivered in person or sent by registered mail at the address to Procuring Agency as given in Bidding Data.

#### **D. SUBMISSION OF BID**

##### **IB.15 Deadline for Submission, Modification & Withdrawal of Bids**

15.1 Bids must be received by the Procuring Agency at the address/provided in Bidding Data not later than the time and date stipulated therein.

15.2 The inner and outer envelopes shall:

- a) be addressed to the Procuring Agency at the address provided in the Bidding Data;
- b) bear the name and identification number of the Contract as defined in the Bidding and Contract Data; and
- c) provide a warning not to open before the specified time and date for Bid opening as defined in the Bidding Data
- d) in addition to the identification required in 15.2, the inner envelopes shall indicate the name and address of the Bidder to enable the Bid to be returned unopened incase it is declared late.
- e) If the outer envelope is not sealed and marked as above, the Procuring Agency will assume no responsibility for the misplacement or premature opening of the Bid.

15.3 Bids submitted through telegraph, telex, fax or e-mail shall not be considered.

15.4 Any bid received by the Procuring Agency after the deadline for submission prescribed in Bidding Data will be returned unopened to such bidder.

15.5 Any bidder may modify or withdraw his bid after bid submission provided that the modification or written notice of withdrawal is received by the Procuring Agency prior to the deadline for submission of bids.

15.6 Withdrawal of a bid during the interval between the deadline for submission of bids and the expiration of the period of bid validity specified in the Form of Bid may result in forfeiture of the Bid Security pursuant to IB.13.5 (a).

## **E. BID OPENING AND EVALUATION**

### **IB.16 Bid Opening, Clarification and Evaluation (SPP Rules 41, 42 & 43)**

16.1 The Procuring Agency will open the bids, in the presence of bidders representatives who choose to attend, at the time, date and in the place specified in the Bidding Data.

16.2 The bidder's name, Bid Prices, any discount, the presence or absence of Bid Security, and such other details as the Procuring Agency at its discretion may consider appropriate, will be announced by the Procuring Agency at the bid opening. The Procuring Agency will record the minutes of the bid opening. Representatives of the bidders who choose to attend shall sign the attendance sheet.

Any Bid Price or discount which is not read out and recorded at bid opening will not be taken into account in the evaluation of bid.

16.3 To assist in the examination, evaluation and comparison of Bids the Engineer/Procuring Agency may, at its discretion, ask the bidder for a clarification of its Bid. The request for clarification and the response shall be in writing and no change in the price or substance of the Bid shall be sought, offered or permitted (SPP Rule 43).

16.4 (a) Prior to the detailed evaluation, pursuant to IB.16.7 to 16.9, the Engineer/Procuring Agency will determine the substantial responsiveness of each bid to the Bidding Documents. For purpose of these instructions, a substantially responsive bid is one which conforms to all the terms and conditions of the Bidding Documents without material deviations. It will include determining the requirements listed in Bidding Data.

(b) Arithmetical errors will be rectified on the following basis:

If there is a discrepancy between the unit price and total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected. If there is a discrepancy between the words and figures the amount in words shall prevail. If there is a discrepancy between the Total Bid price entered in Form of Bid and the total shown in Schedule of Prices-Summary, the amount stated in the Form of Bid will be corrected by the Procuring Agency in accordance with the Corrected Schedule of Prices.

If the bidder does not accept the corrected amount of Bid, his Bid will be rejected and his Bid Security forfeited.

16.5 A Bid determined as substantially non-responsive will be rejected and will not subsequently be made responsive by the bidder by correction of the non-conformity.

16.6 Any minor informality or non-conformity or irregularity in a Bid which does not constitute a material deviation (**major deviation**) may be waived by Procuring Agency, provided such waiver does not prejudice or affect the relative ranking of any other bidders.

**(A). Major (material) Deviations include:-**

- i. has not been properly signed;
- ii. is not accompanied by the bid security of required amount and manner;
- iii. stipulating price adjustment when fixed price bids were called for;
- iv. failing to respond to specifications;
- v. failing to comply with Mile-stones/Critical dates provided in Bidding Documents;
- vi. sub-contracting contrary to the Conditions of Contract specified in Bidding Documents;
- vii. refusing to bear important responsibilities and liabilities allocated in the Bidding Documents, such as performance guarantees and insurance coverage;
- viii. taking exception to critical provisions such as applicable law, taxes and duties and dispute resolution procedures;
- ix. a material deviation or reservation is one :
  - a. which affect in any substantial way the scope, quality or performance of the works;
  - b. Adoption/rectification whereof would affect unfairly the competitive position of other bidders presenting substantially responsive bids.

**(B) Minor Deviations**

Bids that offer deviations acceptable to the Procuring Agency and which can be assigned a monetary value may be considered substantially responsive at least as to the issue of fairness. This value would however be added as an adjustment for evaluation purposes only during the detailed evaluation process.

16.7 The Engineer/Procuring Agency will evaluate and compare only the bids previously determined to be substantially responsive pursuant to IB.16.4 to 16.6 as per requirements given hereunder. Bids will be evaluated for complete scope of works. The prices will be compared on the basis of the Evaluated Bid Price pursuant to IB.16.8 herein below.

**Technical Evaluation:** It will be examined in detail whether the works offered by the bidder complies with the Technical Provisions of the Bidding Documents. For this purpose, the bidder's data submitted with the bid in Schedule B to Bid will be compared with technical features/criteria of the works detailed in the Technical Provisions. Other technical information submitted with the bid regarding the Scope of Work will also be reviewed.

## 16.8 Evaluated Bid Price

In evaluating the bids, the Engineer/Procuring Agency will determine for each bid in addition to the Bid Price, the following factors (adjustments) in the manner and to the extent indicated below to determine the Evaluated Bid Price:

- i. making any correction for arithmetic errors pursuant to IB.16.4 hereof.
- ii. discount, if any, offered by the bidders as also read out and recorded at the time of bid opening.
- iii. Excluding **provisional sums** and the provisions for **contingencies** in the Bill of Quantities **if any**, but including **Day work**, where priced competitively.

## IB.17 Process to be Confidential

17.1 Subject to IB.16.3 heretofore, no bidder shall contact Engineer/Procuring Agency on any matter relating to its Bid from the time of the Bid opening to the time the bid evaluation result is announced by the Procuring Agency. The evaluation result shall be announced at least seven (07) days prior to award of Contract (SPP Rule 45). The announcement to all bidders will include table(s) comprising read out prices, discounted prices, price adjustments made, final evaluated prices and recommendations against all the bids evaluated.

17.2 Any effort by a bidder to influence Engineer/Procuring Agency in the Bid evaluation, Bid comparison or Contract Award decisions may result in the rejection of his Bid. Whereas any bidder feeling aggrieved, may lodge a written complaint to Complaint Redressal Committee as per terms and conditions mentioned in SPP Rules 31 & 32. However, mere fact of lodging a complaint shall not warrant suspension of procurement process.

17.3 Bidders may be excluded if involved in “**Corrupt and Fraudulent Practices**” means either one or any combination of the practices given below SPP Rule 2(q);

- i. “**Coercive Practice**” means any impairing or harming, or threatening to impair or harm, directly or indirectly, any party or the property of the party to influence the actions of a party to achieve a wrongful gain or to cause a wrongful loss to another party;
- ii. “**Collusive Practice**” means any arrangement between two or more parties to the procurement process or contract execution, designed to achieve with or without the knowledge of the procuring agency to establish prices at artificial, noncompetitive levels for any wrongful gain;
- iii. “**Corrupt Practice**” means the offering, giving, receiving or soliciting, directly or indirectly, of anything of value to influence the acts of another party for wrongful gain;
- iv. “**Fraudulent Practice**” means any act or omission, including a misrepresentation, that knowingly or recklessly misleads, or attempts to mislead, a party to obtain a financial or other benefit or to avoid an obligation;
- v. “**Obstructive Practice**” means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in a procurement process, or effect the execution of a contract or deliberately destroying, falsifying, altering or concealing of evidence material to the investigation or making false statements before investigators in order to materially impede an investigation into allegations of a corrupt, fraudulent, coercive or collusive practice; or threatening, harassing or intimidating any party to prevent it from

disclosing its knowledge of matters relevant to the investigation or from pursuing the investigation, or acts intended to materially impede the exercise of inspection and audit rights provided for under the rules

## **F. AWARD OF CONTRACT**

### **IB.18. Post Qualification**

18.1 The Procuring Agency, at any stage of the bid evaluation, having credible reasons for or *prima facie* evidence of any defect in contractor's capacities, may require the contractors to provide information concerning their professional, technical, financial, legal or managerial competence whether already pre-qualified or not:

Provided, that such qualification shall only be laid down after recording reasons therefore in writing. They shall form part of the records of that bid evaluation report.

18.2 The determination will take into account the bidder's financial and technical capabilities. It will be based upon an examination of the documentary evidence of the bidders qualifications submitted under B.11, as well as such other information required in the Bidding Documents.

### **IB.19 Award Criteria & Procuring Agency's Right**

19.1 Subject to IB.19.2, the Procuring Agency will award the Contract to the bidder whose bid has been determined to be substantially responsive to the Bidding Documents and who has offered the lowest evaluated Bid Price, provided that such bidder has been determined to be qualified to satisfactorily perform the Contract in accordance with the provisions of the IB.18.

19.2 Notwithstanding IB.19.1, the Procuring Agency reserves the right to accept or reject any bid, and to annul the bidding process and reject all bids, at any time prior to award of Contract, without thereby incurring any liability to the affected bidders or any obligation to inform the affected bidders of the grounds for the Procuring Agency's action except that the grounds for its rejection of all bids shall upon request be communicated, to any bidder who submitted a bid, without justification of the grounds. Notice of the rejection of all the bids shall be given promptly to all the bidders (SPP Rule 25).

### **IB.20 Notification of Award & Signing of Contract Agreement**

20.1 Prior to expiration of the period of bid validity prescribed by the Procuring Agency, the Procuring Agency will notify the successful bidder in writing ("Letter of Acceptance") that his bid has been accepted (SPP Rule 49).

20.2 Within seven (07) days from the date of furnishing of acceptable Performance Security under the Conditions of Contract, the Procuring Agency will send the successful bidder the Form of Contract Agreement provided in the Bidding Documents, incorporating all agreements between the parties.

20.3 The formal Agreement between the Procuring Agency and the successful bidder duly stamped at rate according to Stamp Act 1899 applicable in Sindh of bid price(updated from time to time) stated in Letter of Acceptance shall be executed within seven (07) days of the receipt of Form of Contract Agreement by the successful bidder from the Procuring Agency.



### **IB.21 Performance Security**

21.1 The successful bidder shall furnish to the Procuring Agency a Performance Security of 10% of the contract value in the form and the amount stipulated in the Conditions of Contract within a period of fourteen (14) days after the receipt of Letter of Acceptance (SPP 39).

21.2 Failure of the successful bidder to comply with the requirements of Sub-Clauses IB.20.2& 20.3 or 21.1 or Clause IB.22 shall constitute sufficient grounds for the annulment of the award and forfeiture of the Bid Security.

21.3 Publication of Award of Contract: within seven days of the award of contract, the procuring agency shall publish on the website of the authority and on its own website, if such a website exists, the results of the bidding process, identifying the bid through procurement identifying Number if any and the following information:

1. Evaluation Report;
2. Form of Contract and letter of Award;
3. Bill of Quantities or Schedule of Requirements. (SPP Rule 50)

### **IB.22 Integrity Pact**

The Bidder shall sign and stamp the Form of Integrity Pact provided at Schedule-F to Bid in the Bidding Document for all Sindh Government procurement contracts exceeding Rupees ten (10) million. Failure to provide such Integrity Pact shall make the bid non responsive (SPP Rule 89).

## **BIDDING DATA**

(The following specific data for the works to be tendered shall complement, amend, or supplement the provisions in the Instructions to Bidders. Wherever there is a conflict, the provisions herein shall prevail over those in the Instructions to Bidders.)

### **Instructions to Bidders**

#### **A. Method of Procurement:**

Single Stage Two Envelope Procedure

- i. Bid shall comprise of a single package containing two separate envelopes. Each envelope shall contain separately the financial proposal and the technical proposal;
- ii. Envelopes shall be marked as “**FINANCIAL PROPOSAL**” and “**TECHNICAL PROPOSAL**” in bold and legible letters to avoid confusion;
- iii. Initially, only the envelope marked “**TECHNICAL PROPOSAL**” shall be opened;
- iv. Envelope marked as “**FINANCIAL PROPOSAL**” shall be retained in the custody of the procuring agency without being opened;
- v. Procuring agency shall evaluate the technical proposal in a manner prescribed in given “**Bid Evaluation Criteria**” in the bidding document, without reference to the price and reject any proposal which does not conform to the specified requirements;
- vi. No amendments in the technical proposal shall be permitted after submission of technical proposal;
- vii. Financial proposals of technically qualified bids shall be opened publicly at a time, date and venue announced and communicated to the bidders in advance;
- viii. Financial proposal of bids found technically non-responsive shall be returned unopened to the respective bidders; and
- ix. Bid found to be the lowest evaluated shall be accepted

#### **1.1 Name of Procuring Agency**

Directorate of Alternative Energy, Energy Department, Government of Sindh, Karachi

#### **Brief Description of Works**

The scope of this work comprises Supply, Installation of Solar PV Systems at one hundred and fifty four (154) Schools in district Sujawal, 3 years Operation & Maintenance services with online monitoring system and connection with HESCO for Net Metering (if possible) of the following types of solar PV Systems:

<b>S/NO.</b>	<b>Solar PV System Type</b>	<b>Qty.</b>
1	1.08 kWp	33
2	2.1 KW	78
3	3.2 kWp	19
4	5.4 kW	5
5	8.6 kWp	13
6	15.1 kW	3
7	28.5 kW	3

Systems		154
Schools		154

The firm/service provider/contractor will be responsible for supply of Solar PV Systems with online monitoring system, their installation at site, and three (3) years complete operation & maintenance services and connection of solar PV system with HESCO for Net Metering (if possible) including warranty period. Hence, the contractor shall itself be or may have in association with AEDB certified installer for net metering purpose only. Also, the contractor may itself be or may have a sub-contractor duly licensed by Electric Inspectorate Hyderabad Region.

All the material must be procured from renowned and reputable manufacturers and must comply with the specification/ standards/ certifications mentioned in the technical criteria.

### 1.2 Procuring Agency's Address:

Directorate of Alternative Energy, Energy Department, Government of Sindh, 3<sup>rd</sup> Floor, State Life Building No. 3, Dr. Ziauddin Ahmed Road, Opposite CM House, Karachi, Phone: 02199207144, Fax: 02199206276

1.3 Bid shall be quoted entirely in Pak. Rupees. The payment shall be made in Pak. Rupees.

1.4 The bidder has the financial, technical and constructional capability necessary to perform the Contract as follows:

#### I. Financial capacity:

- a. Documentary evidence established that the bidder is financially sound and is qualified to perform the contract if its bid is accepted.
- b. Must have minimum turnover of Rs.240.00 million average over last three years.

#### II. Technical capacity:

- a. Bidder must have valid registration with following Government Departments
  - i. Pakistan Engineering Council in category **C-3 (minimum), EE-04, and EE-11 (Solar)**
  - ii. Relevant Tax authorities i.e. for income tax and sales tax
  - iii. Sindh Revenue Board (may have valid registration or must have applied for SRB Registration).
  - iv. Electric Inspectorate Hyderabad Region (contractor by itself or a sub-contractor)
  - v. Bidder may itself be Alternative Energy Development Board (AEDB) certified installer or may have a certified installer in association for net metering.
- b. The Bidder shall have minimum three (3) years' experience of solar PV systems installation.
- c. The bidder should have undertaken at least one Project of Solar Solution worth Rs.240.00 million or above during last three years (3).
- d. Experience of execution of similar projects.
- e. Must have experienced staff available in the relevant field

- f. Bidder will provide written Power of Attorney authorizing the signatory of the bidder to act for and on behalf of the bidder (if applicable).
- g. The firm must not be black listed by any firm or government authority

III. Following Document **properly flagged / marked** shall be submitted with technical bids (one original plus two copies):

- i. Copy of valid Pakistan Engineering Council Certificate in categories C-3 (or above), EE-04, and EE-11 (Solar);
- ii. Copy of Income Tax Certificate;
- iii. Copy of General Sales Tax Certificate;
- iv. Copy of Registration Certificate with Sindh Revenue Board or proof of SRB registration under process);
- v. Copy of Registration with Electric Inspectorate Hyderabad Region (contractor or sub-contractor);
- vi. Copy of AEDB Certified Installer Certificate (contractor or associate);
- vii. Audited financial statements of last three years/or any other legal proof of financial stability (whichever is applicable);
- viii. List of technical staff available for this work and their CVs;
- ix. List of similar assignments minimum two (2) projects under-taken over the past 3 years and their completion certificates;
- x. Affidavit on Rs.100 non judicial stamp paper that firm has never been black listed in any organization i.e. Public Sector;
- xi. Technical Compliance Sheet on “Schedule B to Bid” form;
- xii. Specification of the offered products in form of list supported by brochures;
- xiii. In case of joint ventures/associated firms participating with principal firm, a letter of support must be provided in favor of bidder firm by the supporting firms for this particular project. The JV will be evaluated as per PEC Byelaws; and
- xiv. Any other document if asked by the PA to submit at any stage of procurement.

IV. Following Document shall be submitted with financial bids (one original, two copies):

- i. Duly Filled Price Schedule on “Schedule A to Bid” form
- ii. Bid Money of 2.5% of total offered bid in form and shape as given in “**Instruction to Bidder**”

1.5. (a) A detailed description of the Works, essential technical and performance characteristics.

(b) Complete set of technical information, description data, literature and drawings as required in accordance with Schedule B to Bid, Specific Works Data. This will include but not be limited to a sufficient number of drawings, photographs, catalogues, illustrations and such other information as is necessary to illustrate clearly the significant characteristics such as general construction dimensions and other relevant information about the works to be performed.

### 1.6 Amount of Bid Security

Amount of Bid Security is 2.5% of total offered bid amount/estimated cost (refundable) in form and shape as given in “**Instruction to bidder**”

### **1.7 Period of Bid Validity**

Validity period of this bid is 90 days

### **1.8 Number of Copies of the Bid to be submitted:**

One (1) original and two (2) copies

### **1.9 (a) Procuring Agency's Address for the Purpose of Bid Submission**

Directorate of Alternative Energy, Energy Department, Government of Sindh

3<sup>rd</sup> Floor, State Life Building No. 3, Dr. Ziauddin Ahmed Road, Opposite CM House, Karachi.

### **1.10 Deadline for Submission of Bids**

Time: 03:30 pm on 27<sup>th</sup> June, 2023.

### **1.11 Venue, Time, and Date of Bid Opening**

Venue: Committee Room, Energy Department, Government of Sindh, Karachi.

3<sup>rd</sup> Floor, State Life Building No. 3, Dr. Ziauddin Ahmed Road, Opposite CM House, Karachi.

Phone: 02199207144, 02199206448 **Fax:** 02199206276

Time: 04:00 pm on 27<sup>th</sup> June, 2023.

## 1.12 BID EVALUATION CRITERIA:



**GOVERNMENT OF SINDH**  
**Directorate of Alternative Energy**  
**ENERGY DEPARTMENT**

**Bid Evaluation Criteria for Procurement of Solar PV Systems for Schools in district  
 Sujawal**

**Bid Evaluation Check List**

Sr. No.	Item		Contractor No. 1	Contractor No. 2
1	Specific Works Data			
2	Separate Technical & Financial Bids			
3	P.E.C. Registration			
	C3 or above			
	EE04			
	EE11 (solar)			
4	Income Tax Registration			
5	Sales Tax Registration			
6	Registration with Sindh Revenue Board or Applied for SRB			
7	List of similar projects undertaken			
8	Project of Solar Solution undertaken worth Rs.245.00 million or above			
9	At least 3 years experience in Solar Energy Field			
10	List of Experienced Staff with CVs			
11	Certificate of Non Blacklisting			
12	Financial Statement of last 3 Years/or any other legal proof of financial stability (whichever is applicable)			
13	Financial stability (minimum turnover of Rs.245.00 Million)			
14	Schedule B to bid duly filled			
15	Response on Schedule C to bid			
16	Response on Schedule D to bid			
<b>Remarks</b>				

**Technical Evaluation Methods**

<b>Sr. No.</b>		<b>Coefficient</b>		
<b>Bidder will be qualified for financial opening if attained 70% marks</b>				
1	Understanding of the Assignment	5		
2	Quality of staff	5		
3	Financial stability (Turn over Rs.245.00 million (5-Marks), Rs.490.00 million (10-Marks).	10		
4	Previous experience in similar projects-Letter on performance of installed systems from departments be attached	10		
5	Quality of the project implementation /management plan	10		
6	Operation and Maintenance strategy	10		
7	User information strategy	5		
8	PV panel	10		
9	Charge Controller	5		
10	Battery	10		
11	Inverter	10		
12	Remote Monitoring System	5		
13	Cabinet & Mounting Structure	5		
<b>Total</b>		100		
<b>Qualified for Financial Opening (Yes/No)</b>				

**1.13 Detailed requirement of Solar PV Systems for one hundred and fifty four (154) Schools in Districts Sujawal:**

SR.No.	M SR.No.	TALUKA	SCHOOL NAME	SEMIS CODE	U/C	System
1	1	SHAH BUNDER	GBPS MUHAMMAD JAT	404070167	CH. J.KHAN	1.08
2	3	SHAH BUNDER	GBPS ABDUL QADIR SHAH	404070168	CHUHAR JAMALI	3.2
3	4	SHAH BUNDER	GBPS HAJI ALI MUHAMMAD JAT	404070004	CHUHAR JAMALI	2.1
4	5	SHAH BUNDER	GBPS SHAH YAQIQUE	404070190	CHUHAR JAMALI	3.2
5	6	SHAH BUNDER	GBPS O/C CHUHAR JAMALI	404070113	CHUHAR JAMALI	2.1
6	7	SHAH BUNDER	GBPS DARYA KAN JATOI	404070123	LADIYOON	2.1
7	8	SHAH BUNDER	GBPS MURAD ALI MURGHAL	404070185	CHUHAR JAMALI	3.2
8	9	SHAH BUNDER	GBPS JUMAN SANGHAR	404070046	CHUHAR JAMALI	1.08
9	10	SHAH BUNDER	GBPS HUSSAIN DAL	404070044	CHUHAR JAMALI	1.08
10	11	SHAH BUNDER	GBPS JIAND ZANGEJO	404070035	CHUHAR JAMALI	2.1
11	12	SHAH BUNDER	GBPS USMAN OTHO	404070153	CHUHAR JAMALI	1.08
12	13	SHAH BUNDER	GBPS MEHMOOD KHASKHELI	404070110	CHUHAR JAMALI	1.08
13	15	SHAH BUNDER	GBPS GBPS MOLVI FATEH ALI	404070192	LADIYOON	2.1
14	17	SHAH BUNDER	GBPS KANTO MORI	404070147	GOOGANI	3.2
15	18	SHAH BUNDER	GBPS GUL SHEER SANJRANI	404070184	CHUHAR JAMALI	2.1
16	19	SHAH BUNDER	GBPS GUL MUHAMMAD LAGHARI	404070025	CH. J.KHAN	2.1
17	20	SHAH BUNDER	GBPS JAFFR BAHAR	404070140	CH. J.KHAN	2.1
18	21	SHAH BUNDER	GBPS TILLAN SHAH	404070214	LADIYOON	2.1
19	23	SHAH BUNDER	GBPS CHUHAR JAMALI	404070186	CHUHAR JAMALI	5.4
20	26	SHAH BUNDER	GBPS RAMZAN JAT	404070138	SHAH BUNDER	1.08
21	44	SUJAWAL	GBPS SUBHAN PUNJABI	404080035		2.1
22	45	SUJAWAL	GBPS HAJI BAHAWAL KHAN MAGSI	404080154		3.2



23	56	SUJAWAL	GBPS M. KHAN TAHERANI	404080115		2.1
24	68	SUJAWAL	GBPS BUDHO TALPUR	404080203		2.1
25	71	SUJAWAL	GBPS MOHSIN SHAH	404080147		2.1
26	92	SUJAWAL	GBPS QADIR DINO SHAH	404080385		2.1
27	95	SUJAWAL	GBPS SYEDPUR	404080439		2.1
28	128	SUJAWAL	GBPS CHHURETANI	404080124		2.1
29	129	SUJAWAL	GBPS SHAH NAWAZ LAGHARI	404080127		2.1
30	131	SUJAWAL	GBPS KARIM DINO SHAH	404080371		2.1
31	162	SUJAWAL	GBPS NODO BARAN	404080140		2.1
32	175	SUJAWAL	GBPS JAAR	404080149		2.1
33	179	SUJAWAL	CIVIL HOSPITAL SUJAWAL	404080155		2.1
34	180	SUJAWAL	GBPS MADARSA SITE SUJAWAL	404080153		3.2
35	181	SUJAWAL	GBPS MADARSA HASHMIA SUJAWAL	404080445		3.2
36	182	SUJAWAL	GBPS MAIN PRIMARY SINDHI CHANDIA SCHOOL	404080378		5.4
37	183	SUJAWAL	GBPS PACCA SHADE	404080100		2.1
38	208	JATI	GBPS MUGHAL BHEEN	404020355	JATI TOWN	8.6
39	209	JATI	GBPS JATI TOWN	404020356	JATI TOWN	5.4
40	210	JATI	GBPS MUHAMMAD KHAN MALKANI	404020364	M.B. KHAN	2.1
41	218	JATI	GBPS BOHAR	404020429	MUGHAL BHEEN	2.1
42	219	JATI	GBPS RAJ MALIK	928830052	KARMALIK	2.1
43	221	JATI	GBPS MUHAMMAD KHAN GURMANI	404020370	M. KHOSO	2.1
44	222	JATI	GBPS SOOMAR KHAN BURGHARI	404020373	M. KHOSO	2.1
45	225	JATI	GBPS MOOSA MALKANI	404020211	G.M BARAN	2.1
46	226	JATI	GBPS RAHIM DINO BARAN	404020231	G.M BARAN	2.1
47	227	JATI	GBPS HASHIM MALLAH @ BOLLA ESSA BARAN	404020285	G.M BARAN	2.1
48	230	JATI	GBPS MANDHREA	404020344	BEGNA	2.1
49	232	JATI	GBPS MOOSA TAJAN BARAN	404020383	M.B. KHAN	2.1
50	239	JATI	GBPS BEGNA	404020092	BEGNA	3.2
51	241	JATI	GBPS HAJI KHAN SAMEJO	404020095	BEGNA	2.1
52	257	JATI	GGPS MUHAMMAD RAHIM PALIJO	404020259	JATI TOWN	2.1

53	264	JATI	GGPS GHULAM NABI THAHEEM @HAJI UMER JAT	404020234	BEGNA	2.1
54	270	MIR PUR BATHORO	MIRPUR BATHORO	404050079	TC Bathoro	5.4
55	271	MIR PUR BATHORO	MIR PUR BATHORO 2	404050538	TC Bathoro	3.2
56	272	MIR PUR BATHORO	MADRASA USMANIA	404050421	TC Bathoro	5.4
57	292	MIR PUR BATHORO	MUREED JARREJO	404050081	Kamaro	2.1
58	327	MIR PUR BATHORO	JATI CHOWK	404050089	D K Soho	2.1
59	362	MIR PUR BATHORO	LAKHA	404050108	Akber Shah	2.1
60	365	MIR PUR BATHORO	ALI MUHAMMAD THAHIM	404050169	Akber Shah	2.1
61	384	MIR PUR BATHORO	DARRO I	404050124	TC Darro	8.6
62	385	MIR PUR BATHORO	DARRO II	404050123	TC Darro	2.1
63	386	MIR PUR BATHORO	ARBAB GUL MUHAMMAD MEMON	404050129	TC Darro	2.1
64	392	MIR PUR BATHORO	DR. MUHAMMAD BUX KANDHRO	404050183	UC Darro	2.1
65	395	MIR PUR BATHORO	TAHIR SOOMRO	404050461	UC Darro	2.1
66	396	MIR PUR BATHORO	QASIM SOOMRO	404050463	UC Darro	2.1
67	400	MIR PUR BATHORO	LAIKPUR	404050134	Laik Pur	2.1
68	419	MIR PUR BATHORO	BACHAL GUGO	404050158	B/Gugo	1.08
69	421	MIR PUR BATHORO	SOOMAR LASHARI	404050054	B/Gugo	1.08
70	427	MIR PUR BATHORO	DOORO DHAMACH	404050159	B/Gugo	1.08
71	429	MIR PUR BATHORO	JEHAN KHAN MANGSI	404050162	B/Gugo	2.1
72	430	MIR PUR BATHORO	BACHAL MANGSI	404050180	B/Gugo	1.2
73	431	MIR PUR BATHORO	MUHAMMED SOOMAR NAHIO	404050203	B/Gugo	1.08
74	433	MIR PUR BATHORO	ALI MUHAMMAD GUGO	404050473	B/Gugo	1.08
75	434	MIR PUR BATHORO	MOLVI AHMED GUGO	404050475	B/Gugo	1.08
76	436	MIR PUR BATHORO	DABO MORI	404050157	B/Gugo	1.08
77	439	MIR PUR BATHORO	GUL GAHO	404050465	B/Gugo	1.08
78	457	MIR PUR BATHORO	BANOO	404050145	Banno	3.2

79	462	MIR PUR BATHORO	RAHOOTH	404050296	Banno	2.1
80	466	MIR PUR BATHORO	GGPS. Mir Pur Bathoro	404050258	TC Bathoro	3.2
81	467	MIR PUR BATHORO	GGPS. Molvi Hussain Zour	404050314	Shah M Shah	2.1
82	479	MIR PUR BATHORO	GGPS. Main Darro	404050278	TC Darro	3.2
83	480	MIR PUR BATHORO	GGPS. Arbab Khamiso	404050301	TC Darro	2.1
84	482	MIR PUR BATHORO	GGPS. Tahir Soomro	404050271	UC Darro	3.2
85	488	MIR PUR BATHORO	GGPS. Bachal Gugo	404050265	Bachal Gugo	1.08
86	489	MIR PUR BATHORO	GGPS. Jumoon Solangi	404050283	Bachal Gugo	1.08
87	495	MIR PUR BATHORO	GGPS. Rahoth	404050254	Banno	2.1
88	498	SUJAWAL	GGPS SAEEDPUR	404080297	Ali Bahar	2.1
89	499	SUJAWAL	GGPS ALI MUHAMMAD SAMON	404080294	Bello	1.2
90	500	SUJAWAL	GGPS MUHAMMAD KHAN BIJORA	404080300	Bello	1.08
91	501	SUJAWAL	GGSP MUHAMMAD IBRAHIM Bijoro	404080307	Bello	1.08
92	502	SUJAWAL	GGPS ABDULLAH GOTO	404080316	Bello	1.08
93	505	SUJAWAL	GGPS KHAMISO PATHAN	404080286	Ghotaro	1.08
94	506	SUJAWAL	GGPS HAJI KHAN HITHYAR	404080275	Sujawal	1.08
95	508	SUJAWAL	GGPS NOHO WALRO	404080288	Bello	1.08
96	510	SUJAWAL	GGPS ALLAHDINO AMRO	404080313	Keenjhar	1.08
97	511	SUJAWAL	GGPS M.C BUDHO TALPUR	404080304	Mirzo	3.2
98	512	SUJAWAL	GGPS HAMZO KHASKHELI	404080234	Ghotaro	1.08
99	513	SUJAWAL	GGPS HASSAN JAKHRO	404080281	Mirzo	1.08
100	514	SUJAWAL	GGPS MUHAMMAD IBRAHIM BARAN	404080301	Mirzo	1.08
101	515	SUJAWAL	GGPS BARRAGE COLONY	404080279	Sujawal	1.08
102	516	SUJAWAL	GGPS CIVIL HOSPITAL SUJAWAL	404080278	Sujawal	2.1
103	517	SUJAWAL	GGPS ABDUL MAJEED CHAWAN	928797887	Sujawal	1.08
104	518	SUJAWAL	GGPS MUHAMMAD KHAN PALIPOTO	404080233	Keenjhar	1.08
105	520	Jati	GBHSS - JATI	404020439	Jati- Tc	8.6
106	521	Jati	GBHS - BEGUNAH	404020434	Began	2.1

107	522	Jati	GGHS - TARR KHAWAJA	404020437	Began	28.5
108	523	Jati	GBHS - GUL MUHAMMAD BARAN	404020433	Gul Muhammad	2.1
109	524	Jati	GBLSS - UMER KEHAR @ MALIA MORI	404020428	Gul Muhammad	2.1
110	525	Jati	GBLSS - AMEEN KHASKHELI	404020427	Kar Malik	2.1
111	526	Jati	GBLSS - BUHAR (BR)	404020429	Kar Malik	2.1
112	527	Jati	GBLSS - RAJ MALIK	404020426	Kar Malik	2.1
113	529	Jati	GBHS - MUREED KHOSO	404020436	Mureed Khoso	8.6
114	530	Jati	GGLSS - MUREED KHOSO	404020432	Mureed Khoso	3.2
115	531	Mirpur Bithoro	GBHSS - DARRO	404050588	DARRO- Tc	8.6
116	532	Mirpur Bithoro	GGHSS - BATHORO	404050590	BATHORO - Tc	28.5
117	533	Mirpur Bithoro	GGHSS - DARRO	404050589	DARRO- Tc	8.6
118	534	Mirpur Bithoro	GGLSS - LAKHA	404050577	Ali Akbar Shah	2.1
119	535	Mirpur Bithoro	GBLSS - BACHAL GUGO	404050574	Bachal Gugo	2.1
120	536	Mirpur Bithoro	GBHS - AHMED KHAN PALIJO	404050583	Bano	2.1
121	537	Mirpur Bithoro	GBHSS - BANNO	404050585	Bano	8.6
122	538	Mirpur Bithoro	GBHS - DAWOOD PERHIYAR	404050581	Darya Khan Suhoo	3.2
123	539	Mirpur Bithoro	GGLSS - BANNU	404050282	Darya Khan Suhoo	2.1
124	540	Mirpur Bithoro	GBHSS - JHOKE SHARIF	404050586	Jhoke Sharif	15.1
125	541	Mirpur Bithoro	GBLSS - MUREED JAREJO	404050576	Kamaro	2.1
126	542	Mirpur Bithoro	GBHS - ESSA BIKAK	404050584	Laoqpur	2.1
127	543	Mirpur Bithoro	GBHS - LAIKPUR	404050582	Laoqpur	2.1
128	544	Mirpur Bithoro	GBLSS - MEHMOOD WAH	404050575	Mehar Shah	2.1
129	545	Mirpur Bithoro	GGLSS - MEMONKI	404050579	Shah Muhammad	2.1
130	546	Shah Bundar	GBHS - CHUHAR JAMALI	404070230	Chouhar Jamali	8.6
131	547	Shah Bundar	GGLSS - CHUHAR JAMALI	404070222	Chouhar Jamali	2.1
132	548	Shah Bundar	GBHS - GUNGANI	404070229	Goongani	8.6

133	549	Shah Bundar	GBLSS - ALI MUHAMMAD MEMON	404070231	Goongani	3.2
134	550	Shah Bundar	GBLSS - AGEDINO SHAH	404070226	Jugo Jalbani	2.1
135	551	Shah Bundar	GBLSS - HUSSAIN DAL	404070220	Jugo Jalbani	3.2
136	552	Shah Bundar	GBLSS - JEAND ZANGEJO	404070221	Jugo Jalbani	2.1
137	553	Shah Bundar	GBHS - CHACHH JEHAN KHAN	404070228	Ladiyoon	8.6
138	554	Shah Bundar	GBHS - LADYOON	404070227	Ladiyoon	15.1
139	555	Sujawal	GBHS - SUJAWAL	404080442	Sujawal - Tc	15.1
140	556	Sujawal	GGHS - SUJAWAL	404080445	Sujawal - Tc	8.6
141	557	Sujawal	GBLSS - SAEEDPUR	404080439	Ali Bahar	2.1
142	558	Sujawal	GBHS - BELLO	404080441	Bello	28.5
143	559	Sujawal	GBLSS - IBRAHIM TARARO	404080402	Ghotaro	1.08
144	560	Sujawal	GBHS - CHURETANI	404080440	Jar	2.1
145	561	Sujawal	GBLSS - JAR	404080435	Jar	2.1
146	563	Sujawal	GBELS - USMAN SOOMRO	404080170	Kheeral	2.1
147	564	Sujawal	GBHS - KHIZERABAD	404080443	Mirzo Laghari	8.6
148	565	Sujawal	GBHS - NODO BARAN	404080444	Mirzo Laghari	2.1
149	566	Sujawal	GGLSS - KHIZERABAD	404080437	Mirzo Laghari	2.1
150	567	Sujawal	GGLSS - NODO BARAN	404080292	Mirzo Laghari	1.2
151	568	Sujawal	GBLSS - KOT ALMOON	404080433	MuradPur	2.1
152	569	Sujawal	GBLSS - RANTA	404080434	MuradPur	3.2
153	570	Jati	GBLSS - HAJI HASHIM BARAN	904000095	Shah Kapoor	2.1
154	571	Latifabad	Govt. Modern High School Latifabad	403030189		8.6

## PROPOSED SOLAR SYSTEMS FOR DIFFERENT CATEGORIES

### A. TECHNICAL SPECIFICATION OF 1.08 kWp SOLAR PV SYSTEM:

#### **Solar PV System Design:**

<b>Item</b>	<b>Specification</b>	<b>Qty</b>
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)* 1080 Watt or higher.	01
Inverter	Hybrid Inverter 1200W	01
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation (As per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 12V	2
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618)Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01

### B. TECHNICAL SPECIFICATION OF 2.1 kWp SOLAR PV SYSTEM:

#### **Solar PV System Design:**

<b>Item</b>	<b>Specification</b>	<b>Qty</b>
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)* 2100 Watt or higher.	01
Inverter	Hybrid Inverter – 1200 Watts	02
3 phase meter for net metering	As per requirement of the concerned DISCO	01
Panel Mounting Structure	GI / Aluminum Standard Mounting – L1 /L2	Lot
Civil Work	Size of foundation (As per site requirement)	-

AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 12V	02
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618)Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	Lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	Lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design, Battery bank Cabinet	02

#### A. TECHNICAL SPECIFICATION OF 3.2 kWp SOLAR PV SYSTEM:

### Solar PV System Design:

Item	Specification	Qty
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)*3200Watt or higher.	01
Inverter	Hybrid Inverter, 3600Watt	01
Three phase meter	As per requirement of concerned DISCO	01
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation pads (As per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 48V	01
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618) Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot

accessories		
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01

#### A. TECHNICAL SPECIFICATION OF 5.4 kWp SOLAR PV SYSTEM:

### Solar PV System Design:

Item	Specification	Qty
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)* 5400 Watt or higher.	01
Inverter	Hybrid Inverter 5kW	01
Three Phase meter for net metering	As per requirement of concerned DISCO	01
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation (as per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 48V	2
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618) Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01



### C. TECHNICAL SPECIFICATION OF 8.6 kWp SOLAR PV SYSTEM:

#### Solar PV System Design:

Item	Specification	Qty
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)* 8600 Watt or higher.	01
Inverter	Hybrid Inverter 8000Watt	01
Three phase meter for net metering	As per requirement of DISCO	01
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation (As per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 48V	02
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618)Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01

### B. TECHNICAL SPECIFICATION OF 15.1 kWp SOLAR PV SYSTEM:

## Solar PV System Design:

Item	Specification	Qty
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier1)* 15100 Watt or higher.	01
Inverter	Hybrid Inverter 12000W	01
3 Phase meter for net metering	As per requirement of concerned DISCO	01
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation (as per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 48V	3
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618) Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01

### **C. TECHNICAL SPECIFICATION OF 28.5 kWp SOLAR PV SYSTEM:**

#### *Solar PV System Design:*

Item	Specification	Qty
Solar PV	High efficiency, 4 Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier 1)* 28500 Watt or higher.	01
Inverters	Hybrid Inverter, 12000 Watt	02
3 Phase meter for Net	As per requirement of the concerned DISCO	01

Metering		
Panel Mounting Structure	GI / Aluminum Standard Mounting - L2/L3	Lot
Civil Work	Size of foundation (As per site requirement)	-
AC/ DC Protection & Switchgear	DC Fuses, DC Breaker, AC Breaker, AC SPD, DB	-
Battery	Li-ion 100Ah, 48V	03
Cables	DC Cable- 4sqmm/ 6sqmm – Flexible - EN50618)Panel to panel Earthing – 2.5 sqmm 1 core) AC Stranded - 4c (Cu/PVC/PVC)	lot
Grounding	Earth pit	As per capacity
Ducting and other accessories	Cable Duct, UPVC Pipe, Bolting, Connectors, etc.	lot
Transportation & Installation	-	-
Design Engineering	Civil design details with drawing Structural design detail with drawings Electrical design details: Safety and Protections design and plan	-
Testing, Commissioning, and Audit		-
System Cabinet	Efficient natural and forced cooling design	01

# FORM OF BID AND SCHEDULES TO BID

## ***FORM OF BID (LETTER OF OFFER)***

Bid Reference No. \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

*(Name of Works)*

To:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Gentlemen,

1. Having examined the Bidding Documents including Instructions to Bidders, Bidding Data, Conditions of Contract, Contract Data, Specifications, Drawings, if any, Schedule of Prices and Addenda Nos. \_\_\_\_\_ for the execution of the above-named works, we, the undersigned, being a company doing business under the name of and address

\_\_\_\_\_ and being duly incorporated under the laws of Pakistan hereby offer to execute and complete such works and remedy any defects therein in conformity with the said Documents including Addenda thereto for the Total Bid Price of Rs \_\_\_\_\_ (Rupees \_\_\_\_\_) or such other sum as may be ascertained in accordance with the said Documents.

2. We understand that all the Schedules attached hereto form part of this Bid.

3. As security for due performance of the undertakings and obligations of this Bid, we submit herewith a Bid Security in the amount of \_\_\_\_\_ drawn in your favor or made payable to you and valid for a period of twenty eight (28) days beyond the period of validity of Bid.

4. We undertake, if our Bid is accepted, to commence the Works and to deliver and complete the Works comprised in the Contract within the time(s) stated in Contract Data.

5. We agree to abide by this Bid for the period of \_\_\_\_\_ days from the date fixed for receiving the same and it shall remain binding upon us and may be accepted at any time before the expiration of that period.

6. Unless and until a formal Agreement is prepared and executed, this Bid, together with your written acceptance thereof, shall constitute a binding contract between us.

7. We undertake, if our Bid is accepted, to execute the Performance Security referred to in Conditions of Contract for the due performance of the Contract.

8. We understand that you are not bound to accept the lowest or any bid you may receive.

9. We do hereby declare that the Bid is made without any collusion, comparison of figures or arrangement with any other person or persons making a bid for the Works.

Dated this \_\_\_\_\_ day of \_\_\_\_\_, 20

Signature \_\_\_\_\_

in the capacity of \_\_\_\_\_ duly authorized to sign bid for and on behalf of

\_\_\_\_\_

*(Name of Bidder in Block Capitals)*

*(Seal)*

Address

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Witness:

(Signature) \_\_\_\_\_

Name: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

**SCHEDULES TO BID INCLUDE THE FOLLOWING:**

- Schedule A to Bid: Schedule of Prices
- Schedule B to Bid: Specific Works Data
- Schedule C to Bid: Proposed Program of Works
- Schedule D to Bid: Method of Performing Works
- Schedule E to Bid: Integrity Pact

## ***PREAMBLE TO SCHEDULE OF PRICES***

### **1. General**

1.1 The Schedule of Prices shall be read in conjunction with the Conditions of Contract, Contract Data together with the Specifications and Drawings, if any.

1.2 The Contract shall be for the whole of the works as described in these Bidding Documents. Bids must be for the complete scope of works.

### **2. Description**

2.1 The general directions and descriptions of works and materials are not necessarily repeated nor summarized in the Schedule of Prices. References to the relevant sections of the Bidding Documents shall be made before entering prices against each item in the Schedule of Prices.

### **3. Units & Abbreviations**

3.1 Units of measurement, symbols and abbreviations expressed in the Bidding Documents shall comply with the Systeme Internationale<sup>e</sup> Unites (SI Units).

### **4. Rates and Prices**

4.1 Except as otherwise expressly provided under the Conditions of Contract, the rates and amounts entered in the Schedule of Prices shall be the rates at which the Contractor shall be paid and shall be the full inclusive value of the works set forth or implied in the Contract; except for the amounts reimbursable, if any to the Contractor under the Contract.

4.2 Unless otherwise stipulated in the Contract Data, the premium, rates and prices entered by the bidder shall not be subject to adjustment during the performance of the Contract.

4.3 All duties, taxes and other levies payable by the Contractor shall be included in the rates and prices.

4.4 The whole cost of complying with the provisions of the Contract shall be included in the items provided in the Schedule of Prices, and where no items are provided, the cost shall be deemed to be distributed among the rates and prices entered for the related items of the Works and no separate payment will be made for those items.

The rates, prices and amounts shall be entered against each item in the Schedule of Prices. Any item against which no rate or price is entered by the bidder will not be paid for by the Procuring Agency when executed and shall be deemed covered by the rates and prices for other items in the Schedule of Prices.

4.5 (a) The bidder shall be deemed to have obtained all information as to and all requirements related thereto which may affect the bid price.

\*(b) The Contractor shall be responsible to make complete arrangements for the transportation and installation of equipment to the Site.

4.6 The Contractor shall provide for all parts of the Works to be completed in every respect. Notwithstanding that any details, accessories, etc. required for the complete installation and satisfactory operation of the Works, are not specifically mentioned in the Specifications, such details shall be considered as included in the Contract Price.

## **5. Bid Prices**

### **5.1 Break-up of Bid Prices**

The various elements of Bid Prices shall be quoted as detailed by the Procuring Agency in the format of Schedule of Prices. The bidder shall recognize such elements of the costs which he expects to incur the performance of the Works and shall include all such costs in the rates and amounts entered in the Schedule of Prices.

### **5.2 Total Bid Price**

The total of bid prices in the Schedule of Prices shall be entered in the Summary of Bid Prices.

## **6. Provisional Sums and Day work**

6.1 Provisional Sums included and so designated in the Schedule of Prices if any, shall be expended in whole or in part at the direction and discretion of the Engineer/Procuring Agency. The Contractor will only receive payment in respect of Provisional Sums, if he has been instructed by the Engineer/Procuring Agency to utilize such sums.

6.2 Day work rates in the contractor's bid are to be used for small additional amounts of work and only when the Engineer have given written instructions in advance for additional work to be paid for in that way.



**SCHEDULE - A TO BID: SCHEDULE OF PRICES – SUMMARY OF BID PRICES**

**A. Price Schedule of Solar PV Systems:**

This table must be filled for each type of solar PV system.

<b>Item</b>	<b>Specification</b>	<b>Make</b>	<b>Model</b>	<b>Country of Origin</b>	<b>Qty.</b>	<b>Price</b>
Solar Modules Certified Tier 1						
Solar Hybrid Inverter						
Battery						
Support Structure and Civil Work						
Protection						
Cabling						
Grounding and 3 phase meter for net metering						
Electrical Accessories (uPVC, Flexible, Bolts etc)						
System Cabinet						
Installation at Site						
Online Monitoring System						
Transportation						
3 Years O&M						
Total Price (Including Transportation, Installation, taxes, 3 Years O&M, Online Monitoring System etc.)						
Total quoted prices (sum of all types of systems)						

**SCHEDULE - B TO BID : SPECIFIC WORKS DATA**

- Bidders shall fill specifications of offered products in the following table.
- Write “compliance” if same specifications are offered and for non-compliance for any specific parameter, mention the offered specification):

Specification	Bidders Offered Specifications																		
<p><b>A. TECHNICAL SPECIFICATION OF 1.08 kWp SOLAR PV SYSTEM:</b></p> <p><b>SYSTEM COMPONENTS:</b></p> <p>Features and technical parameters of the system components shall be as follows:</p> <p style="text-align: center;"><b>1. SOLAR PANEL:</b></p> <p><b>Features and Specifications:</b></p> <ul style="list-style-type: none"> <li>a) High efficiency, 4 or more Bus bars or more, Mono (preferably half-cell PERC) solar panel, with corrosion resistant Alframes (Tier 1)*</li> <li>b) Front Cover: 3.2mm high transmission, low iron, tempered glass</li> <li>c) Junction Box: IP65/IP67</li> <li>d) Operating temperature: - 40°C to 85 °C</li> <li>e) Module Efficiency: 18.14% or higher</li> <li>f) Warranty: 5 years</li> <li>g) Certifications               <ul style="list-style-type: none"> <li>• IEC 61215, IEC 61730, UL 61730</li> <li>• ISO 9001:2015: ISO Quality Management System</li> <li>• ISO 14001: 2015: ISO Environment Management System</li> <li>• TS62941: Guideline for module design qualification and type approval</li> <li>• ISO 45001: 2018: Occupational Health and Safety</li> </ul> </li> </ul> <p style="text-align: center;"><b>2. INVERTER:</b></p> <p>Hybrid Inverter detail specifications are as follows</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="text-align: center;">Battery Input Data</th> </tr> </thead> <tbody> <tr> <td>Battery Type</td> <td style="text-align: center;">Li-ion</td> </tr> <tr> <td>Battery Voltage</td> <td style="text-align: center;">12 VDC</td> </tr> <tr> <td>Max Charging Current</td> <td style="text-align: center;">60A</td> </tr> <tr> <td>Over Charging Protection</td> <td style="text-align: center;">16VDC</td> </tr> <tr> <th colspan="2" style="text-align: center;">PV String Input Data (Solar Charger &amp; AC Charger)</th> </tr> <tr> <td>Max. PV Input Open Circuit Voltage</td> <td style="text-align: center;">102 VDC</td> </tr> <tr> <td>Max. PV Input Power</td> <td style="text-align: center;">700 W</td> </tr> <tr> <td>Max. PV Input Current</td> <td style="text-align: center;">46A</td> </tr> </tbody> </table>		Battery Input Data		Battery Type	Li-ion	Battery Voltage	12 VDC	Max Charging Current	60A	Over Charging Protection	16VDC	PV String Input Data (Solar Charger & AC Charger)		Max. PV Input Open Circuit Voltage	102 VDC	Max. PV Input Power	700 W	Max. PV Input Current	46A
Battery Input Data																			
Battery Type	Li-ion																		
Battery Voltage	12 VDC																		
Max Charging Current	60A																		
Over Charging Protection	16VDC																		
PV String Input Data (Solar Charger & AC Charger)																			
Max. PV Input Open Circuit Voltage	102 VDC																		
Max. PV Input Power	700 W																		
Max. PV Input Current	46A																		

MPP Range @ Operating Voltage	15-80 VDC
Max. Solar Charge Current	50A
Max. AC Charge Current	20A
Max. Charge Current	60A
<b>AC Output Data</b>	
Max. Output Power	1200W
AC rated output Current	50 A
Max AC Current	20 A
Power Factor	01
Output frequency	50h / 60hz
<b>Efficiency</b>	
MPPT Efficiency	90% - 93%
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II
Grid Regulation	UL1714, IEEE1547, RULE21, VDE0216, AS4777, NRS2017, G98, G99, IEC61683, IEC62116, IEC61727
Safety Regulation	IEC62109-1, IEC62109-2
EMC	EN61000-6-1, EN61000-6-3, FCC 15 class B

### 3. BATTERY

Parameter	Specification
Battery Type	Lithium-ion Battery
Rated Voltage	12V
Nominal Voltage	12.8V
Rated Capacity	100Ah, 12V
Discharge Current max.	130A (1.66W)
Discharge cut-off Voltage	10V
Charge Current (Recomm.)	20A
Charge Current (Max)	50A
Charge Voltage	14.4V ± 0.2V
<b>Temperature Range</b>	
Discharge	-20 to + 60 C
Charge	0 to + 45 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharge	+15 to +35 C
Charge	+15 to +35 C
Storage	+15 to +35 C

#### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

S. No	SPECIFICATION	VALUE
1	Certification for protection	PV electrical protections to be designed based IEC62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

## 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

S. No	SPECIFICATION	VALUE
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

## 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing

2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

#### 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

### 8. SYSTEM CABINET

#### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

#### B. TECHNICAL SPECIFICATION OF 2.1 kWp SOLAR PV SYSTEM:

##### SYSTEM COMPONENTS:

Features and technical parameters of the system components shall be as follows:

#### 1. SOLAR PANEL:

##### Features and Specifications:

- High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC) Mono PERC solar panel, with corrosion resistant Al frames (Tier 1)\*
- Front Cover: 3.2mm high transmission, low iron, tempered glass

- b) Junction Box: IP65/IP67
- c) Operating temperature: - 40°C to 85 °C
- d) Module Efficiency: 18.14% or higher
- e) Warranty: 5 years
- f) Certifications
  - IEC 61215, IEC 61730, UL 61730
  - ISO 9001:2015: ISO Quality Management System
  - ISO 14001: 2015: ISO Environment Management System
  - TS62941: Guideline for module design qualification and type approval
  - ISO 45001: 2018: Occupational Health and Safety

## 2. INVERTER:

Hybrid Inverter detail specifications are as follows

<b>Battery Input Data</b>	
Battery Type	Li-ion
Battery Voltage	12 VDC
Max Charging Current	60A
Over Charging Protection	16VDC
<b>PV String Input Data (Solar Charger &amp; AC Charger)</b>	
Max. PV Input Open Circuit Voltage	102 VDC
Max. PV Input Power	700 W
Max. PV Input Current	46A
MPP Range @ Operating Voltage	15-80 VDC
Max. Solar Charge Current	50A
Max. AC Charge Current	20A
Max. Charge Current	60A
<b>AC Output Data</b>	
Max. Output Power	1200W
AC rated output Current	50 A
Max AC Current	20 A
Power Factor	01
Output frequency	50h / 60hz
<b>Efficiency</b>	
MPPT Efficiency	90% - 93%
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II
Grid Regulation	UL1714, IEEE1547, RULE21, VDE0216, AS4777, NRS2017, G98, G99, IEC61683, IEC62116, IEC61727
Safety Regulation	IEC62109-1, IEC62109-2
EMC	EN61000-6-1, EN61000-6-3, FCC 15 class B

### 3. BATTERY

#### Features & Specifications

Parameter	Specification
Battery Type	Lithium-ion Battery
Rated Voltage	12V
Nominal Voltage	12.8V
Rated Capacity	100Ah, 12V
Discharge Current max.	130A (1.66W)
Discharge cut-off Voltage	10V
Charge Current (Recomm.)	20A
Charge Current (Max)	50A
Charge Voltage	14.4V ± 0.2V
<b>Temperature Range</b>	
Discharge	-20 to + 60 C
Charge	0 to + 45 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharge	+15 to +35 C
Charge	+15 to +35 C
Storage	+15 to +35 C

### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

S. No	SPECIFICATION	VALUE
1	Certification for protection	PV electrical protections to be designed based IEC 62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

### 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

S. No	SPECIFICATION	VALUE
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

## 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

## 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP



## 8. SYSTEM CABINET

### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

### B. TECHNICAL SPECIFICATION OF 3.2 kWp SOLAR PV SYSTEM:

#### SYSTEM COMPONENTS:

Features and technical parameters of the system components shall be as follows:

#### 1. SOLAR PANEL:

##### Features and Specifications:

- a) High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier 1)\*
- b) Front Cover: Tempered glass/3.2 mm
- c) Junction Box (IP68, three diodes)
- d) Operating temperature: -40°C to 85 °C
- e) Module Efficiency 21.1% or higher
- f) Warranty 25 years
- g) Certifications
  - IEC 61215, IEC 61730, UL 61730
  - ISO 9001:2015: ISO Quality Management System
  - ISO 14001: 2015: ISO Environment Management System
  - TS62941: Guideline for module design qualification and type approval
  - ISO 45001: 2018: Occupational Health and Safety

#### 2. INVERTER:

Hybrid Inverter detail specifications are as follows

Battery Input Data	
Battery Type	Li-ion
Battery Voltage Range	40 ~ 60 V
Max Charging Current	120A
Charging Curve	3 Stages / Equalization
Charging Strategy for Li-ion Battery	Self-Adaption of BSD

<b>PV String Input Data</b>	
Max. DC input Power	4680W
PV input Voltage	370 ~ 500V
MPPT Range	125 ~ 425V
Full load DC Voltage Range	240 ~ 425 V
Startup Voltage	125V
PV Input Current	14A
<b>AC Output Data</b>	
Rated AC Output	3600W
Max. Output Power	3960W
AC rated output Current	15.7 A
Max AC Current	18 A
Power Factor	01
Output frequency and Voltage Range	50Hz, 220/240V
<b>Efficiency</b>	
MPPT Efficiency	98 %
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II
Grid Regulation	VDE0216, AS4777, NRS2017, G98, G99
Safety Regulation	IEC62109-1, IEC62109-2
EMC	EN61000-6-1, EN61000-6-3, FCC 15 class B
05 years	

### 3. BATTERY

#### Features & Specifications

<b>Parameter</b>	<b>Specification</b>
Battery Type	Lithium-ion Battery
Rated Voltage	48V
Rated Capacity	100Ah, 48V
Discharge Current max.	100A
Discharge end Voltage	40.5V
Charge Current (Recomm.)	20A
Charge Current (Max)	100A
Charge Voltage	54±0.5V
<b>Temperature Range</b>	
Discharge	-20 to + 60 C
Charge	0 to + 60 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharge	+15 to +35 C

Charge Storage	+15 to +35 C +15 to +35 C
Self-discharge	<3-4%/month @ 25C according to IEC Standards
Certification	ISO9001:2015, ISO14001:2015, OHSAS18001:2007, SA8000:2014, TL9000-H R5.5 / R5.0 Certificate
Manufacturing date	< 6 months before installation
Warranty	5 years

#### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

S. No	SPECIFICATION	VALUE
1	Certification for protection	PV electrical protections to be designed based IEC 62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

#### 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

S. No	SPECIFICATION	VALUE
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

#### 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

#### 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

### 8. SYSTEM CABINET

#### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

#### C. TECHNICAL SPECIFICATION OF 5.4 kWp SOLAR PV SYSTEM:

##### SYSTEM COMPONENTS:

Features and technical parameters of the system components shall be as follows:

# 1. SOLAR PANEL:

## Features and Specifications:

- a) High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosionresistant Al frames (Tier 1)\*
- b) Front Cover: Tempered glass/3.2 mm
- c) Junction Box (IP68, three diodes)
- d) Operating temperature: - 40°C to 85 °C
- e) Module Efficiency 21.1% or higher
- f) Warranty 25 years
- g) Certifications
  - ✓ IEC 61215, IEC 61730, UL 61730
  - ✓ ISO 9001:2015: ISO Quality Management System
  - ✓ ISO 14001: 2015: ISO Environment Management System
- ✓ TS62941: Guideline for module design qualification and type approval
- ✓ ISO 45001: 2018: Occupational Health and Safety

# 2. INVERTER:

Hybrid Inverter detail specifications are as follows

<b>Battery Input Data</b>	
Battery Type	Li-ion
Battery Voltage Range	40 ~ 60 V
Max Charging Current	120A
Charging Curve	3 Stages / Equalization
Charging Strategy for Li-ion Battery	Self-Adaption of BSD
<b>PV String Input Data</b>	
Max. DC input Power	6500
PV input Voltage	370 ~ 500V
MPPT Range	125 ~ 425V
Full load DC Voltage Range	240 ~ 425 V
Startup Voltage	125V
PV Input Current	11/11A
<b>AC Output Data</b>	
Rated AC Output	5000W
Max. Output Power	5500W
AC rated output Current	21.7 A
Max AC Current	25 A
Power Factor	01
Output frequency and Voltage Range	50hz, 220/240V
<b>Efficiency</b>	

MPPT Efficiency	98 %
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II
Grid Regulation	UL1714, IEEE1547, RULE21, VDE0216, AS4777, NRS2017, G98, G99, IEC61683, IEC62116, IEC61727
Safety Regulation	IEC62109-1, IEC62109-2
EMC	EN61000-6-1, EN61000-6-3, FCC 15 class B
	05 years

### 3. BATTERY

#### Features & Specifications

Parameter	Specification
Battery Type	Lithium-ion Battery
Rated Voltage	48V
Rated Capacity	100Ah, 48V
Discharge Current max.	100A
Discharge end Voltage	40.5V
Charge Current (Recomm.)	20A
Charge Current (Max)	100A
Charge Voltage	54±0.5V
<b>Temperature Range</b>	
Discharge	-20 to + 60 C
Charge	0 to + 60 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharge	+15 to +35 C
Charge	+15 to +35 C
Storage	+15 to +35 C
Self-discharge	<3-4%/month @ 25C according to IEC Standards
Certification	ISO9001:2015, ISO14001:2015, OHSAS18001:2007, SA8000:2014, TL9000-H R5.5 / R5.0 Certificate
Manufacturing date	< 6 months before installation
Warranty	5 years

### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

S. No	SPECIFICATION	VALUE
-------	---------------	-------

1	Certification for protection	PV electrical protections to be designed based IEC 62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

## 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

S. No	SPECIFICATION	VALUE
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

## 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement

3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

**7. AC/ DC PROTECTION & SWITCHGEAR**

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

**8. SYSTEM CABINET**

Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

**D. TECHNICAL SPECIFICATION OF 8.6 kWp SOLAR PV SYSTEM:**

**SYSTEM COMPONENTS:**

Features and technical parameters of the system components shall be as follows:

**1. SOLAR PANEL:**

**Features and Specifications:**

- a) High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosion resistant Al frames (Tier 1)\*



- b) Front Cover: Tempered glass/3.2 mm
- c) Junction Box (IP68, three diodes)
- d) Operating temperature: - 40°C to 85 °C
- e) Module Efficiency 21.1% or higher.
- f) Warranty 25 years
- g) Certifications
  - IEC 61215, IEC 61730, UL 61730
  - ISO 9001:2015: ISO Quality Management System
  - ISO 14001: 2015: ISO Environment Management System
  - TS62941: Guideline for module design qualification and type approval
  - ISO 45001: 2018: Occupational Health and Safety

## 2. INVERTER:

Hybrid Inverter detail specifications are as follows

<b>Battery Input Data</b>	
Battery Type	Li-ion
Battery Voltage Range	40 ~ 60 V
Max Charging Current	150A
Charging Curve	3 Stages / Equalization
Charging Strategy for Li-ion Battery	Self-Adaption of BMS
<b>PV String Input Data</b>	
Max. DC input Power	8000W
PV input Voltage	450V
MPPT Range	120 ~ 430V
Startup Voltage	230V
PV Input Current	36A
<b>AC Output Data</b>	
Max Solar Charge Current	150A
Max AC charge Current	120A
Output frequency and Voltage Range	50/60Hz, 220/230V (single phase)

<b>Efficiency</b>	
MPPT Efficiency	98 %
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II

### 3. BATTERY

#### Features & Specifications

<b>Parameter</b>	<b>Specification</b>
Battery Type	Lithium-ion Battery
Rated Voltage	48V
Rated Capacity	100Ah, 48V
Discharge Current max.	100A
Discharge end Voltage	40.5V
Charge Current (Recomm.)	20A
Charge Current (Max)	100A
Charge Voltage	54±0.5V
<b>Temperature Range</b>	
Discharg	-20 to + 60 C
eCharge	0 to + 60 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharg	+15 to +35 C
eCharge	+15 to +35 C
Storage	+15 to +35 C
Self-discharge	<3-4%/month @ 25C according to IEC Standards
Certification	ISO9001:2015, ISO14001:2015, OHSAS18001:2007, SA8000:2014, TL9000-H R5.5 / R5.0 Certificate
Manufacturing date	< 6 months before installation
Warranty	5 years

### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

<b>S. No</b>	<b>SPECIFICATION</b>	<b>VALUE</b>
1	Certification for protection	PV electrical protections to be designed based IEC 62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

### 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

<b>S. No</b>	<b>SPECIFICATION</b>	<b>VALUE</b>
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

### 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

#### 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

#### 8. SYSTEM CABINET

##### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft

- Material must be MS Powdered Coated

## A. TECHNICAL SPECIFICATION OF 15.1 kWp SOLAR PV SYSTEM:

### SYSTEM COMPONENTS:

Features and technical parameters of the system components shall be as follows:

### 1. SOLAR PANEL:

#### Features and Specifications:

- High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosionresistant Al frames (Tier 1)\*
- Front Cover: Tempered glass/3.2 mm
- Junction Box (IP68, three diodes)
- Operating temperature: - 40°C to 85 °C
- Module Efficiency 21.1% or higher
- Warranty 25 years
- Certifications
  - IEC 61215, IEC 61730, UL 61730
  - ISO 9001:2015: ISO Quality Management System
  - ISO 14001: 2015: ISO Environment Management System
  - TS62941: Guideline for module design qualification and type approval
  - ISO 45001: 2018: Occupational Health and Safety

### 2. INVERTER:

Hybrid Inverter detail specifications are as follows

Battery Input Data	
Battery Type	Li-ion
Battery Voltage Range	40 ~ 60 V
Max Charging Current	240A
Charging Curve	3 Stages / Equalization
Charging Strategy for Li-ion Battery	Self-Adaption to BMS
PV String Input Data	
Max. DC input Power	15600W
PV input Voltage	160 ~ 800V
MPPT Range	200 ~ 650V
Startup Voltage	160V
PV Input Current	26+13A
AC Output Data	

Rated AC Output	12000W
Max. Output Power	13200W
AC rated output Current	18.2/17.4A
Max AC Current	27.3/26.1A
Power Factor	0.8 leading to 0.8 lagging
Output frequency and Voltage Range	50/60Hz, 380/400Vac (three phase)
<b>Efficiency</b>	
MPPT Efficiency	99%
Protection Degree	IP65
Surge Protection	DC Type II, AC Type II
Grid Regulation	EN50549,AS4777.2,VDE0126,IEC61727,VDEN4105,G99,NBT32004,CEI0-21,NRS097,NBR16149/16150,RD1699
Safety Regulation	IEC62109-1/-2, EN61000-6-1, EN61000-6-2, EN61000-6-3, EN61000-6-4
EMC	EN61000-6-1, EN61000-6-3, FCC 15 class B
05 years	

### 3. BATTERY

#### Features & Specifications

Parameter	Specification
Battery Type	Lithium-ion Battery
Rated Voltage	48V
Rated Capacity	100Ah, 48V
Discharge Current max.	100A
Discharge end Voltage	40.5V
Charge Current (Recomm.)	20A
Charge Current (Max)	100A
Charge Voltage	54±0.5V
<b>Temperature Range</b>	
Discharge	-20 to + 60 C
Charge	0 to + 60 C
Storage	0 to + 40 C
<b>Temperature Recommendation</b>	
Discharge	+15 to +35 C
Charge	+15 to +35 C
Storage	+15 to +35 C
Self-discharge	<3-4%/month @ 25C according to IEC Standards

Certification	ISO9001:2015, ISO14001:2015, OHSAS18001:2007, SA8000:2014, TL9000-H R5.5 / R5.0 Certificate
Manufacturing date	< 6 months before installation
Warranty	5 years

#### 4. CABLE AND ELECTRICAL SPECIFICATION

Cable specifications and their requirement are as follows:

S. No	SPECIFICATION	VALUE
1	Certification for protection	PV electrical protections to be designed based IEC 62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

#### 5. PV STRUCTURAL SPECIFICATIONS

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

S. No	SPECIFICATION	VALUE
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3
3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

#### 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
--------	------	---------

1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

#### 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

### 8. SYSTEM CABINET

#### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet
- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

#### E. TECHNICAL SPECIFICATION OF 28.5 kWp SOLAR PV SYSTEM:

##### SYSTEM COMPONENTS:

Features and technical parameters of the system components shall be as follows:

##### 1. SOLAR PANEL:



**Features and Specifications:**

- a) High efficiency, 4 or more Bus bars or more, Monocrystalline (preferably half-cell PERC), with corrosionresistant Al frames (Tier 1)\*
- b) Front Cover: Tempered glass/3.2 mm
- c) Junction Box (IP68, three diodes)
- d) Operating temperature: - 40°C to 85 °C
- e) Module Efficiency 21.1% or higher
- f) Warranty 25 years
- g) Certifications
  - IEC 61215, IEC 61730, UL 61730
  - ISO 9001:2015: ISO Quality Management System
  - ISO 14001: 2015: ISO Environment Management System
  - TS62941: Guideline for module design qualification and type approval
  - ISO 45001: 2018: Occupational Health and Safety

**2. INVERTER:**

Hybrid Inverter detail specifications are as follows

<b>To add single phase it can be converted into three phase</b>	
<b>PV String Input Data</b>	
<b>Three Phase</b>	
Max. DC Input Power	12000W
PV InputVoltage	550 ( 160 ~ 800V )
MPPT Range	200V – 650V
Start-up Voltage (V)	160V
PV InputCurrent	26A + 13A
<b>AC Output Data</b>	
Rated AC output Power	12000W
AC Output Rated Current	18.27/17.4A
Max. AC Current	27.3/26.1A
Output frequency and voltage	( 50/60Hz ) , ( 380/440 )

Operating Temperature Range	-45~ + 60C
<b>Efficiency</b>	
MPPT Efficiency	99%
<b>Protection</b>	
Protection Degree	IP65
Surge Protection	DC Type II , AC Type II
<b>Certifications and Standards</b>	
Grid Regulation	EN50549,AS4777.2,VDE0126,IEC61727,V DEN4105,G99 NBT32004,CEI0- 21,NRS097,NBR16149/16150,RD1699
Safety Regulation	IEC62109-1, IEC62109-2
EMC	IEC62109-1/-2, EN61000-6-1,EN61000- 62,EN61000-6-3,EN61000-6-4
<b>Warranty</b>	
05 years	

### 3. **BATTERY**

#### **Features & Specifications**

<b>Parameter</b>	<b>Specification</b>
Battery Type	Lithium-ion Battery
Rated Voltage	48V
Rated Capacity	100Ah, 48V
Discharge Current max.	100A
Discharge end Voltage	40.5V
Charge Current (Recomm.)	20A
Charge Current (Max)	100A
Charge Voltage	54±0.5V

<b>Temperature Range</b> Discharg eCharge Storage	-20 to + 60 C 0 to + 60 C 0 to + 40 C
<b>Temperature Recommendation</b> Discharg eCharge Storage	+15 to +35 C +15 to +35 C +15 to +35 C
Self-discharge	<3-4%/month @ 25C according to IEC Standards
Certification	ISO9001:2015, ISO14001:2015, OHSAS18001:2007, SA8000:2014, TL9000-H R5.5 / R5.0 Certificate
Manufacturing date	< 6 months before installation
Warranty	5 years

#### **4. CABLE AND ELECTRICAL SPECIFICATION**

Cable specifications and their requirement are as follows:

<b>S. No</b>	<b>SPECIFICATION</b>	<b>VALUE</b>
1	Certification for protection	PV electrical protections to be designed based IEC62548, IEC 61643-32. Should include OCPD, OVP, Lightning Protection
2	Outdoor equipment rating	IP65
3	DC cable	Flexible stranded tinned copper, class 5 conductor, cross-linked polyolefin insulated and sheathed cable. EN50618
4	DC/AC Voltage	Drop less than 2%
5	AC Cable	AC Stranded - 4c (Cu/PVC/PVC)
6	Design and Installation	Following standards should be followed IEC 62548, IEC 62446, IEC 61643-32, IEC 60364-5-52, IEEE 80 Solar Projects

#### **5. PV STRUCTURAL SPECIFICATIONS**

Structure will be built with respect to the properties allowed by the owner following are further specification requirement

<b>S. No</b>	<b>SPECIFICATION</b>	<b>VALUE</b>
1	Wind speed protection	For above 35 m/s continues wind
2	Structure material	GI/Aluminum Standard Mounting - L2/L3

3	Tilt	With respect to location facing south providing maximum output.
4	Certification	ASCE 7-10 – (For Design of Wind Loading) AISC LRFD – (For Design of Structure).

### 6. DESIGN ENGINEERING

S. No.	TYPE	DETAILS
1.	Civil design details with drawing	RCC/ PCC details (as per site specifics) PSI Strength details Weight of Foundation Sectional and side view Layout with sizing
2.	Structural design detail with drawings	Solar Structure design Inverter Structure design (where applicable) Wind load analysis of Solar structure Material details Module placement
3.	Electrical design details:	String Layout Inverter placement Cable route Cable sizing calculations
4.	Safety and Protections design and plan	Earth pits Lighting Protection OCPD OVP String and Isolators

### 7. AC/ DC PROTECTION & SWITCHGEAR

S. No.	Specifications	Details
1.	AC/ DC PROTECTION	DC Fuses, AC Breaker, DC Breaker, AC SPD, DB IP

### 8. SYSTEM CABINET

#### Features and Specifications

- Inverter, battery, Load management devices and all kinds of cables, connectors etc. all of these shall be installed or connected in the cabinet

- Efficient natural and forced cooling design
- Provision to lock, to avoid theft
- Material must be MS Powdered Coated

**A. REMOTE MONITORING SYSTEM**

- a) Remote Monitoring System shall be a state of the art system
- b) Design shall cater scalability, data security and interoperability, standard software and hardware protocols
- c) All components, data logger, operating system computer, router, switches etc. shall be installed in industry standard mode
- d) Real time separate voltage and currents for all components like inverter, controller, battery, solar panel, remote monitoring module
- e) Frequently data collection, analysis, display, transmission and back up of each component work status, the interval shall be less than 30 minutes

## ***SCHEDULE – C TO BID: PROPOSED PROGRAMME OF WORKS***

**Following details must be submitted for evaluation of technical bids duly marked as “Response to Schedule C to bid”**

Bidder shall provide a programme in a bar-chart or Program Evaluation and Review Technique (PERT) or Critical Path Method (CPM) showing the sequence of work items by which he proposes to complete the works of the entire Contract. The programme should indicate the sequence of work items and the period of time during which he proposes to complete the works including the activities like designing, schedule of submittal of drawings, ordering and procurement of materials, manufacturing, delivering, construction of installation works, erection, testing and commissioning of works to be supplied under the Contract

## ***SCHEDULE – D TO BID: METHOD OF PERFORMING WORKS***

**Following details must be submitted for evaluation of technical bids duly marked as “Response to Schedule D to bid”**

The bidder is required to submit a narrative outlining the method of performing the Works duly marked as “**Response to Schedule D to Bid**”. Detailed working on schedule D will help the bidder to prepare exact and doable financial offer. The narrative should indicate in detail and include but not be limited to:

- The sequence and methods in which he proposes to carry out the Works, including the number of shifts per day and hours per shift, he expects to work
- Provide detailed operation & maintenance strategy over next three years
- Provide strategy for training the users/user information strategy
- A list of all major items of construction and plant erection, tools and vehicles proposed to be used in delivering/carrying out the works at site
- The procedure for installation of equipment and transportation of equipment and materials to the site
- Organization chart indicating head office & field office personnel involved in management, supervision and engineering of the Works to be done under the Contract

**SCHEDULE – E TO BID: (INTEGRITY PACT)**

**DECLARATION OF FEES, COMMISSION AND BROKERAGE ETC**

**PAYABLE BY CONTRACTORS**

(FOR CONTRACTS WORTH RS. 10.00 MILLION OR MORE)

Contract No. \_\_\_\_\_ Dated \_\_\_\_\_

Contract Value: \_\_\_\_\_

Contract Title: \_\_\_\_\_

..... [name of Contractor] hereby declares that it has not obtained or induced the procurement of any contract, right, interest, privilege or other obligation or benefit from Government of Sindh (GoS) or any administrative subdivision or agency thereof or any other entity owned or controlled by it (GoS) through any corrupt business practice.

Without limiting the generality of the foregoing, [name of Contractor] represents and warrants that it has fully declared the brokerage, commission, fees etc. paid or payable to anyone and not given or agreed to give and shall not give or agree to give to anyone within or outside Pakistan either directly or indirectly through any natural or juridical person, including its affiliate, agent, associate, broker, consultant, director, promoter, shareholder, sponsor or subsidiary, any commission, gratification, bribe, finder's fee or kickback, whether described as consultation fee or otherwise, with the object of obtaining or inducing the procurement of a contract, right, interest, privilege or other obligation or benefit in whatsoever form from, from Procuring Agency (PA) except that which has been expressly declared pursuant hereto.

[name of Contractor] accepts full responsibility and strict liability that it has made and will make full disclosure of all agreements and arrangements with all persons in respect of or related to the transaction with PA and has not taken any action or will not take any action to circumvent the above declaration, representation or warranty.

[name of Contractor] accepts full responsibility and strict liability for making any false declaration, not making full disclosure, misrepresenting facts or taking any action likely to defeat the purpose of this declaration, representation and warranty. It agrees that any contract, right, interest, privilege or other obligation or benefit obtained or procured as aforesaid shall, without prejudice to any other rights and remedies available to PA under any law, contract or other instrument, be voidable at the option of PA.

Notwithstanding any rights and remedies exercised by PA in this regard, [name of Supplier/Contractor/Consultant] agrees to indemnify PA for any loss or damage incurred by it on account of its corrupt business practices and further pay compensation to PA in an amount equivalent to ten times the sum of any commission, gratification, bribe, finder's fee or kickback given by [name of Contractor] as aforesaid for the purpose of obtaining or inducing the procurement of any contract, right, interest, privilege or other obligation or benefit in whatsoever form from PA.

.....

[Procuring Agency]  
[Contractor]



## **CONDITIONS OF CONTRACT & CONTRACT DATA**

# ***CONDITIONS OF CONTRACT***

## **1. GENERAL PROVISIONS**

### **1.1 Definitions**

In the Contract as defined below, the words and expressions defined shall have the following meanings assigned to them, except where the context requires otherwise:

#### **The Contract**

Contract means the Contract Agreement and the other documents listed in the 1.1.1 Contract Data.

1.1.2 Specifications means the document as listed in the Contract Data, including Procuring Agency's requirements in respect of design to be carried out by the Contractor (if any), and any Variation to such document.

1.1.3 Drawings means the Procuring Agency's drawings of the Works as listed in the Contract Data, and any Variation to such drawings.

#### **Persons**

1.1.4 Procuring Agency means the person named in the Contract Data and the legal successors in title to this person, but not (except with the consent of the Contractor) any assignee.

1.1.5 Contractor means the person named in the Contract Data and the legal successors in title to this person, but not (except with the consent of the Procuring Agency) any assignee.

1.1.6 Party means either the Procuring Agency or the Contractor.

#### **Dates, Times and Periods**

1.1.7 Commencement Date means the date fourteen(14) days after the date the Contract comes into effect or any other date named in the Contract Data.

1.1.8 Day means a calendar day

1.1.9 Time for Completion means the time for completing the Works as stated in the Contract Data (or as extended under Sub-Clause 7.3), calculated from the Commencement Date.

#### **Money and Payments**

1.1.10 Cost means all expenditure properly incurred (or to be incurred) by the Contractor, whether on or off the Site, including overheads and similar charges but does not include any allowance for profit.

#### **Other Definitions**

1.1.11 Contractor's Equipment means all machinery, apparatus and other things required for

the execution of the Works but does not include Materials or Plant intended to form part of the Works.

1.1.12 Country means the Islamic Republic of Pakistan.

1.1.13 Procuring Agency's Risks means those matters listed in Sub-Clause 6.1.

1.1.14 Force Majeure means an event or circumstance which makes performance of a Party's obligations illegal or impracticable and which is beyond that Party's reasonable control.

1.1.15 Materials means things of all kinds (other than Plant) to be supplied and incorporated in the Works by the Contractor.

1.1.16 Plant means the machinery and apparatus intended to form or forming part of the Works.

1.1.17 Site means the places provided by the Procuring Agency where the Works are to be executed, and any other places specified in the Contract as forming part of the Site.

1.1.18 Variation means a change which is instructed by the Engineer/Procuring Agency under Sub-Clause 10.1.

1.1.19 Works means any or all the works whether Supply, Installation, Construction etc. and design (if any) to be performed by the Contractor including temporary works and any variation thereof.

1.1.20 Engineer means the person notified by the Procuring Agency to act as Engineer for the purpose of the Contract and named as such in Contract Data.

## **1.2 Interpretation**

Words importing persons or parties shall include firms and organizations. Words importing singular or one gender shall include plural or the other gender where the context requires.

## **1.3 Priority of Documents**

The documents forming the Contract are to be taken as mutually explanatory of one another. If an ambiguity or discrepancy is found in the documents, the priority of the documents shall be in accordance with the order as listed in the Contract

## **1.4 Law**

The law of the Contract is the relevant Law of Islamic Republic of Pakistan.

## **1.5 Communications**

All Communications related to the Contract shall be in English language.

## **1.6 Statutory Obligations**

The Contractor shall comply with the Laws of Islamic Republic of Pakistan and shall give all notices and pay all fees and other charges in respect of the Works.

## **2. THE PROCURING AGENCY**

### **2.1 Provision of Site**

The Procuring Agency shall provide the Site and right of access thereto at the times stated in the Contract Data.

**Site Investigation Reports** are those that were included in the bidding documents and are factual and interpretative reports about the surface and subsurface conditions at the Site.

### **2.2 Permits etc.**

The Procuring Agency shall, if requested by the Contractor, assist him in applying for permits, licences or approvals which are required for the Works.

### **2.3 Engineer's/Procuring Agency's Instructions**

The Contractor shall comply with all instructions given by the Procuring Agency or the Engineer, if notified by the Procuring Agency, in respect of the Works including the suspension of all or part of the works.

### **2.4 Approvals**

No approval or consent or absence of comment by the Engineer/Procuring Agency shall affect the Contractor's obligations.

## **3. ENGINEER'S/PROCURING AGENCY'S REPRESENTATIVES**

### **3.1 Authorized Person**

The Procuring Agency shall appoint a duly authorized person to act for him and on his behalf for the purposes of this Contract. Such authorized person shall be duly identified in the Contract Data or otherwise notified in writing to the Contractor as soon as he is so appointed. In either case the Procuring Agency shall notify the Contractor, in writing, the precise scope of the authority of such authorized person at the time of his appointment.

### **3.2 Engineer's/Procuring Agency's Representative**

The name and address of Engineer's/Procuring Agency's Representative is given in Contract Data. However the Contractor shall be notified by the Engineer/Procuring Agency, the delegated duties and authority before the Commencement of works.

## **4. THE CONTRACTOR**

### **4.1 General Obligations**

The Contractor shall carry out the works properly and in accordance with the Contract. The Contractor shall provide all supervision, labor, Materials, Plant and Contractor's Equipment which may be required

### **4.2 Contractor's Representative**

The Contractor shall appoint a representative at site on full time basis to supervise the execution of work and to receive instructions on behalf of the Contractor but only after obtaining the consent of the Procuring Agency for such appointment which consent shall not be withheld without plausible

reason(s) by the Procuring Agency. Such authorized representative may be substituted/ replaced by the Contractor at any time during the Contract Period but only after obtaining the consent of the Procuring Agency as aforesaid.

#### **4.3 Subcontracting**

The Contractor shall not subcontract the whole of the works. The Contractor shall not subcontract any part of the works without the consent of the Procuring Agency.

#### **4.4 Performance Security**

The Contractor shall furnish to the Procuring Agency within fourteen (14) days after receipt of Letter of Acceptance a Performance Security 10% of the contract value at the option of the bidder, in the form of Payee's order /Bank Draft or Bank Guarantee from scheduled bank for the amount and validity specified in Contract Data.

### **5. DESIGN BY CONTRACTOR**

#### **5.1 Contractor's Design**

The Contractor shall carry out design to the extent specified, as referred to in the Contract Data. The Contractor shall promptly submit to the Engineer/Procuring Agency all designs prepared by him, within fourteen (14) days of receipt the Engineer/Procuring Agency shall notify any comments or, if the design submitted is not in accordance with the Contract, shall reject it stating the reasons. The Contractor shall not construct any element of the works designed by him within fourteen (14) days after the design has been submitted to the Engineer/Procuring Agency or which has been rejected. Design that has been rejected shall be promptly amended and resubmitted. The Contractor shall resubmit all designs commented on taking these comments into account as necessary.

#### **5.2 Responsibility for Design**

The Contractor shall remain responsible for his bided design and the design under this Clause, both of which shall be fit for the intended purposes defined in the Contract and he shall also remain responsible for any infringement of any patent or copyright in respect of the same. The Engineer/Procuring Agency shall be responsible for the Specifications and Drawings.

### **6. PROCURING AGENCY'S RISKS**

#### **6.1 The Procuring Agency's Risks**

The Procuring Agency's Risks are:-

- a) war, hostilities (whether war be declared or not), invasion, act of foreign enemies, within the Country ;
- b) rebellion, terrorism, revolution, insurrection, military or usurped power, or civil war, within the Country ;
- c) riot, commotion or disorder by persons other than the Contractor's personnel and other employees including the personnel and employees of Sub-Contractors, affecting the Site and/or the Works ;

- d) ionising radiations, or contamination by radio-activity from any nuclear fuel, or from any nuclear waste from the combustion of nuclear fuel, radio-active toxic explosive, or other hazardous properties of any explosive nuclear assembly or nuclear component of such an assembly, except to the extent to which the Contractor/Sub-Contractors may be responsible for the use of any radio-active material ;
- e) Pressure waves caused by aircraft or other aerial devices travelling at sonic or supersonic speeds ;
- f) use or occupation by the Procuring Agency of any part of the Works, except as may be specified in the Contract ;
- g) late handing over of sites, anomalies in drawings, late delivery of designs and drawings of any part of the Works by the Procuring Agency's personnel or by others for whom the Procuring Agency is responsible;
- h) a suspension under Sub-Clause 2.3 unless it is attributable to the Contractor's failure; and
- i) physical obstructions or physical conditions other than climatic conditions, encountered on the Site during the performance of the Works, for which the Contractor immediately notified to the Procuring Agency and accepted by the Procuring Agency.

## **7. TIME FOR COMPLETION**

### **7.1 Execution of the Works**

The Contractor shall commence the Works on the Commencement Date and shall proceed expeditiously and without delay and shall complete the Works, subject to Sub-Clause 7.3 below, within the Time for Completion.

### **7.2 Programme**

Within the time stated in the Contract Data, the Contractor shall submit to the Engineer/Procuring Agency a programme for the Works in the form stated in the Contract Data.

### **7.3 Extension of Time**

The Contractor shall, within such time as may be reasonable under the circumstances, notify the Procuring Agency/Engineer of any event(s) falling within the scope of Sub-Clause 6.1 or 10.3 of these Conditions of Contract and request the Procuring Agency/Engineer for a reasonable extension in the time for the completion of works. Subject to the aforesaid, the Procuring Agency/Engineer shall determine such reasonable extension in the time for the completion of works as may be justified in the light of the details/particulars supplied by the Contractor in connection with the such determination by the Procuring Agency/Engineer within such period as may be prescribed by the Procuring Agency/Engineer for the same; and the Procuring Agency may extend the time for completion as determined.

### **7.4 Late Completion**

If the Contractor fails to complete the Works within the Time for Completion, the Contractor's only liability to the Procuring Agency for such failure shall be to pay the amount as **liquidity damages** stated in the Contract Data for each day for which he fails to complete the Works.

## **8. TAKING-OVER**

### **8.1 Completion**

The Contractor may notify the Engineer/Procuring Agency when he considers that the Works are complete.

### **8.2 Taking-Over Notice**

Within fourteen (14) days of the receipt of the said notice of completion from the Contractor the Procuring Agency/Engineer shall either takeover the completed works and issue a Certificate of Completion to that effect or shall notify the Contractor his reasons for not taking-over the works. While issuing the Certificate of Completion as aforesaid, the Procuring Agency/Engineer may identify any outstanding items of work which the Contractor shall undertake during the Maintenance Period.

## **9. REMEDYING DEFECTS**

### **9.1 Remedying Defects**

The Contractor shall for a period stated in the Contract Data from the date of issue of the Certificate of Completion carry out, at no cost to the Procuring Agency, repair and rectification work which is necessitated by the earlier execution of poor quality of work or use of below specifications material in the execution of Works and which is so identified by the Procuring Agency/Engineer in writing within the said period. Upon expiry of the said period, and subject to the Contractor's faithfully performing his aforesaid obligations, the Procuring Agency/Engineer shall issue a Maintenance Certificate whereupon all obligations of the Contractor under this Contract shall come to an end.

Failure to remedy any such defects or complete outstanding work within a reasonable time shall entitle the Procuring Agency to carry out all necessary works at the Contractor's cost. However, the cost of remedying defects not attributable to the Contractor shall be valued as a Variation.

### **9.2 Uncovering and Testing**

The Engineer/Procuring Agency may give instruction as to the uncovering and/or testing of any work. Unless as a result of an uncovering and/or testing it is established that the Contractor's design, materials, plant or workmanship are not in accordance with the Contract, the Contractor shall be paid for such uncovering and/or testing as a Variation in accordance with Sub-Clause 10.2.

## **10. VARIATIONS AND CLAIMS**

### **10.1 Right to Vary**

The Procuring Agency / Engineer may issue Variation Order(s) in writing. Where for any reason it has not been possible for the Procuring Agency/Engineer to issue such Variations Order(s), the Contractor may confirm any verbal orders given by the Procuring Agency/Engineer in writing and if the same are not refuted/denied by the Procuring Agency/Engineer within ten (10) days of the receipt of such confirmation the same shall be deemed to be a Variation Orders for the purposes of this Sub-Clause.

### **10.2 Valuation of Variations**

Variations shall be valued as follows:

- a) at a lump sum price agreed between the Parties, or
- b) where appropriate, at rates in the Contract, or
- c) in the absence of appropriate rates, the rates in the Contract shall be used as the basis for valuation, or failing which
- d) at appropriate new rates, as may be agreed or which the Engineer/Procuring Agency considers appropriate, or
- e) if the Engineer/Procuring Agency so instructs, at day work rates set out in the Contract Data for which the Contractor shall keep records of hours of labour and Contractor's Equipment, and of Materials, used.

### **10.3 Changes in the Quantities.**

- a) If the final quantity of the work done differs from the quantity in the Bill of Quantities for the particular item by more than 25 percent, provided the change exceeds 1 percent of the Initial Contract Price, the Procuring Agency/Engineer shall adjust the rate to allow for the change and will be valued as per sub clause 10.2.
- b) The Engineer shall not adjust rates from changes in quantities if thereby the Initial Contract Price is exceeded by more than 15 percent, except with the prior approval of the Procuring Agency.
- c) If requested by the Engineer, the contractor shall provide the Engineer with a detailed cost breakdown of any rate in the Bill of Quantities.

### **10.4 Early Warning**

The Contractor shall notify the Engineer/Procuring Agency in writing as soon as he is aware of any circumstance which may delay or disrupt the Works, or which may give rise to a claim for additional payment.

To the extent of the Contractor's failure to notify, which results to the Engineer/Procuring Agency being unable to keep all relevant records or not taking steps to minimize any delay, disruption, or Cost, or the value of any Variation, the Contractor's entitlement to extension of the Time for Completion or additional payment shall be reduced/rejected.

### **10.5 Valuation of Claims**

If the Contractor incurs Cost as a result of any of the Procuring Agency's Risks, the Contractor shall be entitled to the amount of such Cost. If as a result of any Procuring Agency's Risk, it is necessary to change the Works, this shall be dealt with as a Variation subject to Contractor's notification for intention of claim to the Engineer/Procuring Agency within fourteen (14) days of the occurrence of cause.

### **10.6 Variation and Claim Procedure**



The Contractor shall submit to the Engineer/Procuring Agency an itemized detailed breakdown of the value of variations and claims within twenty eight (28) days of the instruction or of the event giving rise to the claim. The Engineer/Procuring Agency shall check and if possible agree the value. In the absence of agreement, the Procuring Agency shall determine the value.

## **11. CONTRACT PRICE AND PAYMENT**

### **11.1 (a) Terms of Payments**

The amount due to the Contractor under any Interim Payment Certificate issued by the Engineer pursuant to this Clause, or to any other terms of the Contract, shall , subject to Clause 11.3, be paid by the Procuring Agency to the Contractor within 30 days after such Interim Payment Certificate has been jointly verified by Procuring Agency and Contractor, or, in the case of the Final Certificate referred to in Sub Clause 11.5, within 60days after such Final Payment Certificate has been jointly verified by Procuring Agency and Contractor;

Provided that the Interim Payment shall be caused in thirty (30) days and Final Payment in 60 days in case of foreign funded project. In the event of the failure of the Procuring Agency to make payment within 90 days then Procuring Agency shall pay to the Contractor compensation at the 28 days rate of KIBOR+2% per annum in local currency and LIBOR+1% for foreign currency, upon all sums unpaid from the date by which the same should have been paid.

### **(b) Valuation of the Works**

The Works shall be valued as provided for in the Contract Data, subject to Clause 10.

### **11.2 Monthly Statements**

The Contractor shall be entitled to be paid at monthly intervals:

- a) the value of the Works executed less to the cumulative amount paid previously; and
- b) value of secured advance on the materials and valuation of variations (if any).

The Contractor shall submit each month to the Engineer/Procuring Agency a statement showing the amounts to which he considers himself entitled.

### **11.3 Interim Payments**

Within a period not exceeding seven (07) days from the date of submission of a statement for interim payment by the Contractor, the Engineer shall verify the same and within a period not exceeding thirty (30/60) days from the said date of submission by the Contractor, the Procuring Agency shall pay to the Contractor the sum subject to adjustment for deduction of the advance payments and retention money.

### **11.4 Retention**

Retention money shall be paid by the Procuring Agency to the Contractor within fourteen (14) days after either the expiry of the period stated in the Contract Data, or the remedying of notified defects, or the completion of outstanding work, all as referred to in Sub-Clause 9.1, whichever is the later.

### **11.5 Final Payment**

Within twenty one (21) days from the date of issuance of the Maintenance Certificate the Contractor shall submit a final account to the Engineer to verify and the Engineer shall verify the same within fourteen (14) days from the date of submission and forward the same to the Procuring Agency together with any documentation reasonably required to enable the Procuring Agency to ascertain the final contract value.

Within sixty (60) days from the date of receipt of the verified final account from the Engineer, the Procuring Agency shall pay to the Contractor any amount due to the Contractor. While making such payment the Procuring Agency may, for reasons to be given to the Contractor in writing, withhold any part or parts of the verified amount.

### **11.6 Currency**

Payment shall be in the currency stated in the Contract Data.

## **12. DEFAULT**

### **12.1 Defaults by Contractor**

If the Contractor abandons the Works, refuses or fails to comply with a valid instruction of the Engineer/Procuring Agency or fails to proceed expeditiously and without delay, or is, despite a written complaint, in breach of the Contract, the Procuring Agency may give notice referring to this Sub-Clause and stating the default.

If the Contractor has not taken all practicable steps to remedy the default within fourteen (14) days after receipt of the Procuring Agency's notice, the Procuring Agency may by a second notice given within a further twenty one (21) days, terminate the Contract. The Contractor shall then demobilize from the Site leaving behind any Contractor's Equipment which the Procuring Agency instructs, in the second notice, to be used for the completion of the Works at the risk and cost of the Contractor.

### **12.2 Defaults by Procuring Agency**

If the Procuring Agency fails to pay in accordance with the Contract, or is, despite a written complaint, in breach of the Contract, the Contractor may give notice referring to this Sub-Clause and stating the default. If the default is not remedied within fourteen (14) days after the Procuring Agency's receipt of this notice, the Contractor may suspend the execution of all or parts of the Works.

If the default is not remedied within twenty eight(28) days after the Procuring Agency's receipt of the Contractor's notice, the Contractor may by a second notice given within a further twenty one (21) days, terminate the Contract. The Contractor shall then demobilise from the Site.

### **12.3 Insolvency**

If a Party is declared insolvent under any applicable law, the other Party may by notice terminate the Contract immediately. The Contractor shall then demobilize from the site leaving behind, in the case of the Contractor's insolvency, any Contractor's Equipment which the Procuring Agency instructs in the notice is to be used for the completion of the Works.

### **12.4 Payment upon Termination**

After termination, the Contractor shall be entitled to payment of the unpaid balance of the value of the works executed and of the Materials and Plant reasonably delivered to the site, adjusted by the following:

- a) any sums to which the Contractor is entitled under Sub-Clause 10.4,
- b) any sums to which the Procuring Agency is entitled,
- c) if the Procuring Agency has terminated under Sub-Clause 12.1 or 12.3, the Procuring Agency shall be entitled to a sum equivalent to twenty percent(20%) of the value of parts of the Works not executed at the date of the termination, and
- d) if the Contractor has terminated under Sub-Clause 12.2 or 12.3 , the Contractor shall be entitled to the cost of his de mobilization together with a sum equivalent to ten percent (10%) of the value of parts of the works not executed at the date of termination.

The net balance due shall be paid or repaid within twenty eight (28) days of the notice of termination.

### **13. RISKS AND RESPONSIBILITIES**

#### **13.1 Contractor's Care of the Works**

Subject to Sub-Clause 9.1, the Contractor shall take full responsibility for the care of the Works from the Commencement Date until the date of the Procuring Agency's/Engineer's issuance of Certificate of Completion under Sub-Clause 8.2. Responsibility shall then pass to the Procuring Agency. If any loss or damage happens to the Works during the above period, the Contractor shall rectify such loss or damage so that the Works conform with the Contract.

Unless the loss or damage happens as a result of any of the Procuring Agency's Risks, the Contractor shall indemnify the Procuring Agency, or his agents against all claims loss, damage and expense arising out of the Works.

#### **13.2 Force Majeure**

If Force Majeure occurs, the Contractor shall notify the Engineer/Procuring Agency immediately. If necessary, the Contractor may suspend the execution of the Works and, to the extent agreed with the Procuring Agency demobilize the Contractor's Equipment.

If the event continues for a period of eighty four (84) days, either Party may then give notice of termination which shall take effect twenty eight (28) days after the giving of the notice.

After termination, the Contractor shall be entitled to payment of the unpaid balance of the value of the Works executed and of the Materials and Plant reasonably delivered to the Site, adjusted by the following:

- a) any sums to which the Contractor is entitled under Sub-Clause 10.4,
- b) the cost of his demobilization, and
- c) less any sums to which the Procuring Agency is entitled.

The net balance due shall be paid or repaid within thirty five (35) days of the notice of termination.

## **14. INSURANCE**

### **14.1 Arrangements**

The Contractor shall, prior to commencing the Works, effect insurances of the types, in the amounts and naming as insured the persons stipulated in the Contract Data except for items (a) to (e) and (i) of the Procuring Agency's Risks under Sub-Clause 6.1. The policies shall be issued by insurers and in terms approved by the Procuring Agency. The Contractor shall provide the Engineer/Procuring Agency with evidence that any required policy is in force and that the premiums have been paid.

### **14.2 Default**

If the Contractor fails to effect or keep in force any of the insurances referred to in the previous Sub-Clause, or fails to provide satisfactory evidence, policies or receipts, the Procuring Agency may, without prejudice to any other right or remedy, effect insurance for the cover relevant to such as a default and pay the premiums due and recover the same plus a sum in percentage given in Contractor Data from any other amounts due to the Contractor.

## **15. RESOLUTION OF DISPUTES**

### **15.1 Engineer's Decision**

If a dispute of any kind whatsoever arises between the Procuring Agency and the Contractor in connection with the works, the matter in dispute shall, in the first place, be referred in writing to the Engineer, with a copy to the other party. Such reference shall state that it is made pursuant to this Clause. No later than the twenty eight (28) days after the day on which he received such reference, the Engineer shall give notice of his decision to the Procuring Agency (Superintending Engineer) and the Contractor.

Unless the Contract has already been repudiated or terminated, the Contractor shall, in every case, continue to proceed with the work with all due diligence, and the Contractor and the Procuring Agency (Superintending Engineer) shall give effect forthwith to every such decision of the Engineer unless and until the same shall be revised, as hereinafter provided in an arbitral award.

### **15.2 Notice of Dissatisfaction**

If a Party is dissatisfied with the decision of the Engineer of consultant or if no decision is given within the time set out in Sub-Clause 15.1 here above, the Party may give notice of dissatisfaction referring to this Sub-Clause within fourteen (14) days of receipt of the decision or the expiry of the time for the decision. If no notice of dissatisfaction is given within the specified time, the decision shall be final and binding on the Parties. If notice of dissatisfaction is given within the specified time, the decision shall be binding on the Parties who shall give effect to it without delay unless and until the decision of the Engineer is revised by an arbitrator.

If a contractor is dissatisfied with the decision of the Engineer of the department or decision is not given in time then he can approach Superintending Engineer within 14 days, in case of dissatisfaction with decision of Superintending Engineer or not decided within 28 days, then arbitration process would be adopted as per clause 15.3.

### **15.3 Arbitration**

A dispute which has been the subject of a notice of dissatisfaction shall be finally settled as per provisions of Arbitration Act 1940 (Act No. X of 1940) and Rules made there under and any statutory modifications thereto. Any hearing shall be held at the place specified in the Contract Data and in the language referred to in Sub-Clause 1.5.

## **16 INTEGRITY PACT**

16.1 If the Contractor or any of his Sub-Contractors, agents or servants is found to have violated or involved in violation of the Integrity Pact signed by the Contractor as Schedule-F to his Bid, then the Procuring Agency shall be entitled to:

- (a) recover from the Contractor an amount equivalent to ten times the sum of any commission, gratification, bribe, finder's fee or kickback given by the Contractor or any of his Sub-Contractors, agents or servants;
- (b) terminate the Contract; and
- (c) recover from the Contractor any loss or damage to the Procuring Agency as a result of such termination or of any other corrupt business practices of the Contractor or any of his Sub-Contractors, agents or servants.

On termination of the Contract under Sub-Para (b) of this Sub-Clause, the Contractor shall demobilize from the site leaving behind Contractor's Equipment which the Procuring Agency instructs, in the termination notice, to be used for the completion of the works at the risk and cost of the Contractor. Payment upon such termination shall be made under Sub-Clause 12.4, in accordance with Sub-Para (c) thereof, after having deducted the amounts due to the Procuring Agency under Sub-Para (a) and (c) of this Sub-Clause.

## **CONTRACT DATA**

### **Sub-Clauses of Conditions of Contract**

#### **1.1.4 The Procuring Agency means**

\_\_\_\_\_, Director, Alternative Energy, Directorate of Alternative Energy,  
Energy Department, Government of Sindh

#### **1.1.5 The Contractor means**

\_\_\_\_\_  
\_\_\_\_\_

**1.1.7 Commencement Date** means the date of issue of Engineer's Notice to Commence which shall be issued within fourteen (14) days of the signing of the Contract Agreement.

#### **1.1.9 Time for Completion:**

\_\_\_\_\_ days of supply & installation, and \_\_\_\_\_ years of operation & maintenance services including warranty period (\_\_\_\_\_ years )

#### **1.3 Documents forming the Contract listed in the order of priority:**

- (a) The Contract Agreement
- (b) Letter of Acceptance
- (c) The completed Form of Bid
- (d) Contract Data
- (e) Conditions of Contract
- (f) The completed Schedules to Bid including Schedule of Prices including Corrigendum and Addendum
- (g) The Drawings, if any (provided by the contractor)
- (h) The Specifications

#### **2.1 Provision of Site:** On the Commencement Date

**3.1 Authorized person:** \_\_\_\_\_, Director, Directorate of Alternative Energy,  
Government of Sindh

#### **3.2 Name and address of Engineer's/Procuring Agency's representative**

Mr. \_\_\_\_\_ Director, Directorate of Alternative Energy,  
Government of Sindh

#### **4.4 Performance Security:**

Amount Rs. \_\_\_\_\_ (Rupees \_\_\_\_\_ only)  
Validity \_\_\_\_\_ years (\_\_\_\_\_ years)

#### **7.2 Programme:**

**Time for submission:** Within fourteen (14) days\* of the Commencement Date.

**Form of programme:** Bar Chart/CPM/PERT

**7.4** Amount payable due to failure to complete shall be 0.075% per day up to a maximum of (10%)

of sum stated in the Letter of Acceptance (Usually the liquidated damages are set between 0.05 percent and 0.10 percent per day.)

### 7.5 **Early Completion**

In case of earlier completion of the Work, the Contractor is entitled to be paid bonus up-to limit and at a rate equivalent to 50% of the relevant limit and rate of liquidated damages stated in the contract data.

### 9.1 **Period for remedying defects**

Two Months (2 months)

### 11.1 **Terms of Payments**

#### **a) Mobilization Advance**

(1) Mobilization Advance up to 10 % of the Contract Price stated in the Letter of Acceptance shall be paid by the Procuring Agency to the Contractor on the works costing Rs.2.5 million or above on following conditions:

- (i) on submission by the Contractor of a Mobilization Advance Guarantee for the full amount of the Advance in the specified form from a Scheduled Bank in Pakistan to the Procuring Agency;
- (ii) Contractor will pay interest on the mobilization advance at the rate of 10% per annum on the advance; and
- (iii) This Advance including the interest shall be recovered in 5 equal installments from the five (05) R.A bills and in case the number of bills is less than five (05) then 1/5 th of the advance **inclusive of the interest** thereon shall be recovered from each bill and the balance together with interest be recovered from the final bill. It may be insured that there is sufficient amount in the final bill to enable recovery of the Mobilization Advance.

OR

#### 2) **Secured Advance on Materials**

(a) The Contractor shall be entitled to receive from the Procuring Agency Secured Advance against an INDENTURE BOND in P W Account Form No. 31(Fin. R. Form No. 2 acceptable to the Procuring Agency of such sum as the Engineer may consider proper in respect of non-perishable materials brought at the Site but not yet incorporated in the Permanent Works provided that:

- (i) The materials are in accordance with the Specifications for the Permanent Works;
- (ii) Such materials have been delivered to the Site and are properly stored and protected against loss or damage or deterioration to the satisfaction and verification of the Engineer but at the risk and cost of the Contractor;
- (iii) The Contractor's records of the requirements, orders, receipts and use of materials are kept in a form approved by the Engineer, and such records shall be available for inspection by the Engineer;
- (iv) The Contractor shall submit with his monthly statement the estimated value of the materials on Site together with such documents as may be required by the Engineer for the purpose of valuation of materials and providing evidence of ownership and payment therefore;
- (v) Ownership of such materials shall be deemed to vest in the Procuring Agency and these materials shall not be removed from the Site or otherwise disposed of without written permission of the Procuring Agency;
- (vi) The sum payable for such materials on Site shall not exceed 75 % of the (i) landed

cost of imported materials, or (ii) ex-factory / ex-warehouse price of locally manufactured or produced materials, or

(iii) market price of stands other materials;

(vii) Secured Advance should not be allowed unless & until the previous advance, if an, fully recovered;

(viii) Detailed account of advances must be kept in part II of running account bill; and

(ix) Secured Advance may be permitted only against materials/quantities anticipated to be consumed / utilized on the work within a period of 3 months from the date of issue of secured advance and definitely not for full quantities of materials for the entire work/contract

(b) Recovery of Secured Advance:

(i) Secured Advance paid to the Contractor under the above provisions shall be effected from the monthly payments on actual consumption basis, but not later than period specified in the rules not more than three months (even if unutilized); other conditions.

(ii) As recoveries are made the outstanding accounts of the items concerned in Part II should be reduced by making deduction entries in the column; deduct quantity utilized in work measured since previous bill, equivalent to the quantities of materials used by the contractor on items of work shown as executed in part I of the bill.

(c) Interim payments: The Contractor shall submit to the Engineer monthly statements of the estimated value of the work completed less the cumulative amount certified previously.

(i) The value of work completed comprises the value of the quantities of the items in the Bill of Quantities completed.

(ii) value of secured advance on the materials and valuation of variations (if any).

(iii) Engineer may exclude any item certified in a previous certificate or reduce the proportion of any item previously certified in any certificate in the light of later information.

(v) Retention money and other advances are to be recovered from the bill submitted by contractor.

**11.2 (a) Valuation of the Works:**

i) Lump sum price with schedules of rates Rs. \_\_\_\_\_/- (details), or

ii) Lump sum price with bill of quantities Rs. \_\_\_\_\_/- (details),

**11.3 Percentage of retention:** Performance Security in the shape of \_\_\_\_\_ an amount of Rs. \_\_\_\_\_ (Rupees \_\_\_\_\_ only) i.e. 10% of offered bid price

**11.6 Currency of payment:** Pak. Rupees

**15.3 Arbitration**

Place of Arbitration: Karachi

**Product Liability**

*(Following conditions may vary subject to any addition or change in agreed conditions and will be finalized before award of contract)*

1. The Seller shall be liable for any lack of conformity in goods.
2. The Seller shall be liable to take data of inverters, batteries and solar panels at least one time in month for a period of one year.
3. The Seller declares that the goods during warranty period from the date of collection by the Buyer will remain fit for the purposes for which the goods would ordinarily be used or during this period will retain specified qualities (hereinafter referred to as the "Warranty Period").



4. If the Buyer discovers any defect during the Warranty Period, the Buyer shall give written notice of the defect to the Seller and not later than within 15 days after such defect had been detected.
5. In the written notice specifying the defect, Seller shall have the following options.
  - a) Replace the defective goods by new one/repair it under warrantee period as stated in warranty document.
  - b) Replace/Repair the defective goods if the defects are repairable which is entirely upon the discretion of the Buyer beyond warrantee period. If repair of goods require more time, then the Seller should provide the alternate solution on temporary basis.
6. The Seller upon receipt a notice from the Buyer stating the defect promptly shall give a written statement and reply whether he accepts the claim for defects or not.

## STANDARD FORMS

*(Note: Standard Forms provided in this document for securities are to be issued by a bank. In case the bidder chooses to issue a bond for accompanying his bid or performance of contract or receipt of advance, the relevant format shall be tailored accordingly without changing the spirit of the Forms of securities).*

**FORM OF BID SECURITY (Bank Guarantee)**

Guarantee No. \_\_\_\_\_

Executed on \_\_\_\_\_

( Letter by the Guarantor to the Procuring Agency)

Name of Guarantor (Scheduled Bank in Pakistan) with address: \_\_\_\_\_

Name of Principal (Bidder) with address: \_\_\_\_\_

Sum of Security (express in words and figures): \_\_\_\_\_

Bid Reference No. \_\_\_\_\_ Date of Bid \_\_\_\_\_

KNOW ALL MEN BY THESE PRESENTS, that in pursuance of the terms of the Bid and at the request of the said Principal, we the Guarantor above-named are held and firmly bound unto the \_\_\_\_\_, (hereinafter called The Procuring Agency ) in the sum stated above, for the payment of which sum well and truly to be made, we bind ourselves, our heirs, executors, administrators and successors, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH, that whereas the Principal has submitted the accompanying Bid numbered and dated as above for \_\_\_\_\_ (Particulars of Bid) to the said Procuring Agency; and

WHEREAS, the Procuring Agency has required as a condition for considering the said Bid that the Principal furnishes a Bid Security in the above said sum to the Procuring Agency, conditioned as under:

- (1) that the Bid Security shall remain valid for a period of twenty eight (28) days beyond the period of validity of the bid;
- (2) that in the event of;
  - (a) the Principal withdraws his Bid during the period of validity of Bid, or
  - (b) the Principal does not accept the correction of his Bid Price, pursuant to Sub-Clause 16.4 (b) of Instructions to Bidders, or
  - (c) failure of the successful bidder to
    - (i) furnish the required Performance Security, in accordance with Sub-Clause IB-21 . 1 of Instructions to Bidders, or
    - (ii) sign the proposed Contract Agreement, in accordance with Sub-Clauses IB-20.2 & 20.3 of Instructions to Bidders, the entire sum be paid immediately to the said Procuring Agency for delayed completion and not as penalty for the successful bidder's failure to perform.

NOW THEREFORE, if the successful bidder shall, within the period specified therefore, on the prescribed form presented to him for signature enter into a formal Contract Agreement with the said Procuring Agency in accordance with his Bid as accepted and furnish within fourteen (14)

days of receipt of Letter of Acceptance, a Performance Security with good and sufficient surety , as may be required, upon the form prescribed by the said Procuring Agency for the faithful performance and proper fulfillment of the said Contract or in the event of non -withdrawal of the said Bid within the time specified then this obligation shall be void and of no effect, but otherwise to remain in full force and effect.

PROVIDED THAT the Guarantor shall forthwith pay to the Procuring Agency the said sum stated above upon first written demand of the Procuring Agency without cavil or argument and without requiring the Procuring Agency to prove or to show grounds or reasons for such demand, notice of which shall be sent by the Procuring Agency by registered post duly addressed to the Guarantor at its address given above.

PROVIDED ALSO THAT the Procuring Agency shall be the sole and final judge for deciding whether the Principal has duly performed his obligations to sign the Contract Agreement and to furnish the requisite Performance Security within the time stated above, or has defaulted in fulfilling said requirements and the Guarantor shall pay without objection the sum stated above upon first written demand from the Procuring Agency forthwith and without any reference to the Principal or any other person.

IN WITNESS WHEREOF, the above bounded Guarantor has executed the instrument under its seal on the date indicated above, the name and seal of the Guarantor being hereto affixed and these presents duly signed by its undersigned representative pursuant to authority of its governing body.

Guarantor (Bank)

Witness:

1. Signature

1. \_\_\_\_\_

2. Name \_\_\_\_\_

3. Title \_\_\_\_\_

Corporate Secretary (Seal)

2. \_\_\_\_\_

(Name, Title & Address)

Corporate Guarantor (Seal)

**FORM OF PERFORMANCE SECURITY (Bank Guarantee)**

Guarantee No. \_\_\_\_\_  
Executed on \_\_\_\_\_

Expiry Date \_\_\_\_\_

(Letter by the Guarantor to the Procuring Agency)

Name of Guarantor (Scheduled Bank in Pakistan) with  
address: \_\_\_\_\_

Name of Principal (Contractor) with  
address: \_\_\_\_\_

Penal Sum of Security (express in words and  
figures) \_\_\_\_\_

Letter of Acceptance No. \_\_\_\_\_ Dated \_\_\_\_\_

KNOW ALL MEN BY THESE PRESENTS, that in pursuance of the terms of the Bidding Documents and above said Letter of Acceptance (hereinafter called the Documents) and at the request of the said Principal we, the Guarantor above named, are held and firmly bound unto the \_\_\_\_\_ (hereinafter called the Procuring Agency) in the penal sum of the amount stated above, for the payment of which sum well and truly to be made to the said Procuring Agency, we bind ourselves, our heirs, executors, administrators and successors, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH, that whereas the Principal has accepted the Procuring Agency's above said Letter of Acceptance for \_\_\_\_\_ (Name of Contract) for the \_\_\_\_\_ (Name of Project).

NOW THEREFORE, if the Principal (Contractor) shall well and truly perform and fulfill all the undertakings, covenants, terms and conditions of the said Documents during the original terms of the said Documents and any extensions thereof that may be granted by the Procuring Agency, with or without notice to the Guarantor, which notice is, hereby, waived and shall also well and truly perform and fulfill all the undertakings, covenants terms and conditions of the Contract and of any and all modifications of the said Documents that may hereafter be made, notice of which modifications to the Guarantor being hereby waived, then, this obligation to be void; otherwise to remain in full force and virtue till all requirements of Clause 9, Remedying Defects, of Conditions of Contract are fulfilled.

Our total liability under this Guarantee is limited to the sum stated above and it is a condition of any liability attaching to us under this Guarantee that the claim for payment in writing shall be received by us within the validity period of this Guarantee, failing which we shall be discharged of our liability, if any, under this Guarantee.

We, \_\_\_\_\_ (the Guarantor), waiving all objections and defenses under the Contract, do hereby irrevocably and independently guarantee to pay to the

Procuring Agency without delay upon the Procuring Agency's first written demand without cavil or arguments and without requiring the Procuring Agency to prove or to show grounds or reasons for such demand any sum or sums up to the amount stated above, against the Procuring Agency's written declaration that the Principal has refused or failed to perform the obligations under the Contract, for which payment will be effected by the Guarantor to Procuring Agency's designated Bank & Account Number.

PROVIDED ALSO THAT the Procuring Agency shall be the sole and final judge for deciding whether the Principal (Contractor) has duly performed his obligations under the Contract or has defaulted in fulfilling said obligations and the Guarantor shall pay without objection any sum or sums up to the amount stated above upon first written demand from the Procuring Agency forthwith and without any reference to the Principal or any other person.

IN WITNESS WHEREOF, the above bounded Guarantor has executed this Instrument under its seal on the date indicated above, the name and corporate seal of the Guarantor being hereto affixed and these presents duly signed by its undersigned representative, pursuant to authority of its governing body.

\_\_\_\_\_  
Guarantor (Bank)

Witness:

1. \_\_\_\_\_

1. Signature \_\_\_\_\_

\_\_\_\_\_  
Corporate Secretary (Seal)

2. Name \_\_\_\_\_

3. Title \_\_\_\_\_

2. \_\_\_\_\_

\_\_\_\_\_  
(Name, Title & Address)

\_\_\_\_\_  
Corporate Guarantor (Seal)

## **FORM OF CONTRACT AGREEMENT**

THIS CONTRACT AGREEMENT (hereinafter called the Agreement ) made on the \_\_\_\_ day of June, 2014 between \_\_\_\_\_, Director, Directorate of Alternative Energy, Energy Department, Government of Sindh (hereinafter called the Procuring Agency ) of the one part and \_\_\_\_\_(add contractor's name, address and phone numbers\_\_\_\_\_)(hereinafter called the Contractor ) of the other part.

WHEREAS the Procuring Agency is desirous that certain Works, viz “\_\_\_\_\_” should be executed by the Contractor and has accepted a Bid by the Contractor for the execution and completion of such Works and the remedying of any defects therein.

NOW this Agreement witnessed as follows:

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Conditions of Contract hereinafter referred to.
2. The following documents after incorporating addenda, if any except those parts relating to Instructions to Bidders, shall be deemed to form and be read and construed as part of this Agreement, viz:
  - (a) The Letter of Acceptance;
  - (b) The completed Form of Bid along with Schedules to Bid;
  - (c) Conditions of Contract & Contract Data;
  - (d) The priced Schedule of Prices/Bill of quantities (BoQ);
  - (e) The Specifications; and
  - (f) The Drawings
3. In consideration of the payments to be made by the Procuring Agency to the Contractor as hereinafter mentioned, the Contractor hereby covenants with the Procuring Agency to execute and complete the Works and remedy defects therein in conformity and in all respects within the provisions of the Contract.
4. The Procuring Agency hereby covenants to pay the Contractor, in consideration of the execution and completion of the Works as per provisions of the Contract, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

IN WITNESS WHEREOF the parties hereto have caused this Contract Agreement to be executed on the day , month and year first before written in accordance with their respective laws.

\_\_\_\_\_  
Signature of the Contactor

(Seal)

\_\_\_\_\_  
Signature of the Procuring Agency

(Seal)

Signed, Sealed and Delivered in the presence of:

Witness:

(Name, Title and Address)

Witness:

(Name, Title and Address)



**MOBILIZATION ADVANCE GUARANTEE**

Guarantee No. \_\_\_\_\_  
Executed on \_\_\_\_\_

(Letter by the Guarantor to the Procuring Agency)

WHEREAS the \_\_\_\_\_ (hereinafter called the Procuring Agency) has entered into a Contract for

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_ (Particulars of Contract), with  
\_\_\_\_\_ (hereinafter called the Contractor).

AND WHEREAS the Procuring Agency has agreed to advance to the Contractor, at the Contractor's request, an amount of Rs. \_\_\_\_\_ Rupees \_\_\_\_\_) which amount shall be advanced to the Contractor as per provisions of the Contract.

AND WHEREAS the Procuring Agency has asked the Contractor to furnish Guarantee to secure the advance payment for the performance of his obligations under the said Contract.

AND WHEREAS \_\_\_\_\_ (Scheduled Bank) (hereinafter called the Guarantor) at the request of the Contractor and in consideration of the Procuring Agency agreeing to make the above advance to the Contractor, has agreed to furnish the said Guarantee.

NOW THEREFORE the Guarantor hereby guarantees that the Contractor shall use the advance for the purpose of above mentioned Contract and if he fails, and commits default in fulfillment of any of his obligations for which the advance payment is made, the Guarantor shall be liable to the Procuring Agency for payment not exceeding the aforementioned amount.

Notice in writing of any default, of which the Procuring Agency shall be the sole and final judge, as aforesaid, on the part of the Contractor, shall be given by the Procuring Agency to the Guarantor, and on such first written demand payment shall be made by the Guarantor of all sums then due under this Guarantee without any reference to the Contractor and without any objection.

This Guarantee shall come into force as soon as the advance payment has been credited to the account of the Contractor.

This Guarantee shall expire not later than \_\_\_\_\_ by which date we must have received any claims by registered letter, telegram, telex or telefax.

It is understood that you will return this Guarantee to us on expiry or after settlement of the total amount to be claimed hereunder.

\_\_\_\_\_  
Guarantor (Scheduled Bank)

Witness:

1. \_\_\_\_\_

\_\_\_\_\_  
Corporate Secretary (Seal)

2. \_\_\_\_\_

\_\_\_\_\_  
(Name, Title & Address)

1. Signature \_\_\_\_\_

2. Name \_\_\_\_\_

3. Title \_\_\_\_\_

\_\_\_\_\_  
Corporate Guarantor (Seal)

**INDENTURE FOR SECURED ADVANCES**

(For use in cases in which is contract is for finished work and the contractor has entered into an agreement for the execution of a certain specified quantity of work in a given time ).

This INDENTURE made the ..... day of .....  
----- -197--"- BETWEEN (hereinafter called "the Contractor" which expression shall where the context so admits or implied be deemed to include his heirs, executors, administrators and assigns) of the one part and THE GOVERNOR OF SINDH (hereinafter called "the Government" of the other part).

WHEREAS by an agreement, dated ( hereinafter called the said agreement, the contractor has agreed to perform the under-mentioned works (hereinafter referred to as the said work):-  
(Here enter (the description of the works).

AND WHEREAS the contractor has applied to the .....  
— ..... ---- for an advance to him of Rupees -----  
(Rs. .... ) on the security of materials absolutely belonging to him and brought by him to the site of the said works the subject of the said agreement f or use in the construction of such of the said works as he has undertaken to execute at rates fixed for the finished work (inclusive of the cost of materials and labour and other charge) AND WHEREAS the Government has agreed to advance to the Contractor the sum of Rupees, (Rs. .... ) on the security of materials the quantities and other particulars of which are detailed in Part II of Running Account Bill (E). the said works signed by the contractor Fin R.Form.17.Aon ----- ..... — and on such covenants and conditions as are hereinafter contained and the Government has reserved to itself the option of marking any further advance or advances on the security of other materials brought by the Contractor to the site of the said works.

NOW THIS INDENTURE WTTNESSETH that in pursuance of the said — ..... agreement and in consideration of the sum of Rupees ..... - ..... (Rs. ----- - ---- ) on or before the execution of these presents paid to the Contractor by the Government (the receipt whereof the Contractor doth hereby acknowledge) and of such further advances (if any) as may be made to him as aforesaid (all of which advances are hereinafter collectively referred to as the said amount) the Contractor doth hereby assign unto the Government the said materials by way of security for the said amount And doth hereby covenant and agree with the Government and declare as follows:

(1) That the said sum of Rupees ..... - ..... (Rs . ----- ---- ) so advanced by the Government to the Contractor as aforesaid and all or any further sum or sums which may be advanced aforesaid shall be employed by the contractor in or towards expending the execution of the said works and for no other purpose whatsoever.

(2) That the materials detailed in the said Running Account Bill (B) which have been (Fin R Form No. 17-A)Offered to and accepted by (he Government as security for the said amount are absolutely by the Contractors own property free from encumbrances of any kind and the Contractor will not make any application for or receive a further advance on the security of materials which are not absolutely his own property and free from encumbrances of any kind and the contractor hereby agrees, at all times, to indemnify and save harmless the Government against all claims whatsoever to any materials in respect of which an advance has been made to him as aforesaid.

(3) That the said materials detailed in the said Running Account Bill (B) and all other (F i n . R . F o r m No. 1 7 -A)

Materials on the security of which any further advance or advances may hereafter be made as aforesaid (hereinafter called the said materials) shall be used by the Contractor solely in *the* execution of the said works in accordance with the directions of the Divisional Officer -----  
----- (hereinafter called the Divisional Officer) and in the terms of the said agreement.

(4) That the Contractor shall make at his own cost all necessary and adequate arrangement for the proper watch, safe custody and protection against all risks of the said material and that until used in construction as aforesaid the said materials shall remain at the site of the said works in the Contractor's custody and at his own risk and on his own responsibility and shall at all times be open to inspection by (he Divisional Officer or any officer authorized by him. In the event of the said materials of any part (hereof being stolen, destroyed or damaged or becoming deteriorated in a grater degree than is due to reasonable use and wear thereof Contractor will forthwith replace the same with other materials of like qualify or repair and make good the same as required by the Divisional Officer and the materials so brought to replace the said materials so repaired and made good shall also be considered as security for the said amount.

(5) 'Hurt the said materials shall not on any account be removed from the site of the said works except with the written permission of the Divisional Officer or an officer authorized by him in that behalf

(6) That the said amount shall be payable in full when or before the Contractor receives payment, from the Government of the price payable to him f or the said works under the terms and provisions of the said agreement PROVIDED THAT if any inter mediate payments are made to the contractor on account of work done then on the occasion of each such payment the Government will be at liberty to make a recovery from the Contractor s Bill for such payment by deducting there from in the value of the said materials (hen actually used in the construction and in respect of which recovery has not been made previously the value f or this purpose being determined in respect of each description of material at (he rates at which the amount of the advances made under these presents were calculated.

(7) That if the Contractor shall at any time make any default in the performance or observation in any respect of any of the terms and provisions of the said agreement or of these presents the total amount of the advance or advances that may still be owing to the Government shall immediately on the happening of such default be repayable by the Contractor to the Government together with interest thereon at twelve percent per annum from the date or respective dates of such advance or advances to the date or repayment and with all costs, charges, damages and expenses incurred by the Government in or for the recovery thereof or the enforcement of this security or otherwise by reason of (he default of the Contractor and any moneys so becoming due and

payable shall constitute a debt due from the Contractor to the Government and the Contractor hereby covenants and agrees with the Government to repay and the same respectively to it accordingly.

(8) That the Contractor hereby charges all the said materials with the repayment to the Government of the said sum of Rupees ..... - .....  
(Rs. ....) and any further sum or sums which may be advanced as aforesaid and all costs charges damages and expenses payable under these present PROVIDED ALWAYS and it is hereby agreed and declared that notwithstanding anything in the said

agreement and without prejudice to the powers contained therein if and whether the covenant for payment and repayment hereinbefore contained shall become enforceable and the money owing shall not be paid to accordingly. Once there with the Government may at any time thereafter adopt all or any of following courses as it may deem best :-

(a) Seize and utilize the said materials or any part thereof in the completion of the said works on behalf of the Contractor in accordance with the provisions in that behalf contained in the said agreement debiting the Contractor with the actual cost of effecting such completion the amount due in respect of advances under these presents and crediting the Contractor with the value of work done as he had carried it out in accordance with the said agreement and at the rates thereby provided. If the balance is against the Contractor he is to pay the same to the Government on demand.

(b) Remove and sell by public auction the seized materials or any part thereof and out of the moneys arising from the sale retain all the sums aforesaid repayable to the Government under these presents and pay over the surplus (if any) to the Contractor.

(c) Deduct all or any part of the moneys owing out of the security deposit or any sum due to the Contractor under the said agreement.

(9) That except as is expressly provided by the presents interest on the aid advance shall not be payable.

(10) That in the event of any conflict between the provisions of these presents and the said agreement the provisions of these presents shall prevail and in the event of any dispute or difference arising over the construction or effect of these presents the settlement of which has not been hereinbefore expressly provided for the same shall be referred to the Superintending Engineer ..... Circle whose..... decision shall be final and the provisions of the Indian Arbitration Act for the time being in force so far as they are applicable shall apply to any such reference.

In witnesses whereof the\* ----- on behalf of the Governor of Sindh and the said ----- - ----- --have hereunto set their respective hands and seals the day and first above written.

Signed, sealed and delivered by\* In the presence of

Seal

1st witness 2<sup>nd</sup> witness

Signed, sealed and delivered by\* In the presence of

Seal

1st Witness witnessed